

# FIRESTOPPING PROJECT DETAILS

**Project:** 

Pathology Unit (St James')

Main Contractor: BAM Construction

Firas URN:

TX1830

Revised 23rd June 2023



# Firestopping Package at Pathology Unit (St James' Hospital for BAM Construction) Agreed Scope of Works

- Sparta are to provide Fire Stopping works under the following scenarios (Anything not mentioned such as Profiled Deck Fillers and Beam Encasements are deemed to be included as part of the General Drylining Package):
  - o Penetrations Seals through Fire Rated Walls
  - Penetration Seals through Fire Rated Floors
  - Linear Seals between Blockwork and Steelwork and between Blockwork and Concrete (Not covered under Firas Accreditation but will be logged on Bolster)
  - Penetrations Seals through Acoustic Rated Walls (Not covered under Firas Accreditation but will be logged on Bolster)
  - Fire Barriers above Ceilings and penetrations of services through them (Installed to manufacturers details but not covered under Firas Accreditation – Penetrations will also be recorded on Bolster)
- There are 2 Substation rooms on the project that require 120min Protection then aside from those the maximum fire rating required on the project is 60 minutes through walls and 60 minutes through floors. These ratings are to be achieved through tested solutions wherever possible. If there has to be a choice over Integrity Rating or Insulation Rating then Fire Integrity rating will be prioritised over Fire Insulation rating.
- Fire Barriers required above ceiling level will be installed to manufacturers
  recommendations and these will fall outside the scope of Sparta's 3<sup>rd</sup> Party Certification.
  Sparta are currently in the process of gaining 3<sup>rd</sup> Party Accreditation for Fire Barriers, if this is
  achieved prior to installing the works on this project then we will cover them under the 3<sup>rd</sup>
  Party Accreditation and inform BAM.
- If for some reason a service penetration can't be sealed to meet the Fire Rating required (i.e. no access or services not installed correctly) then Sparta will identify these to the client as soon as possible in order for an agreement to be made on how to proceed.
- Sparta's chosen product manufacturer is Rockwool, we will endeavour to carry out all works with Rockwool tested details, which on occasion will include using other manufacturers' products in conjunction with Rockwool, such as Ultra Universal Pipe Wrap or Mulcol Multicollar, both of which are supported by Rockwool in certain applications.
- As discussed via emails we will be following the guidance in Approved Document B Volume 2, Section B3, Subsection 10. This states that the openings around pipes up to a certain diameter (Table given within this project pack) can have the opening sealed to the pipe as long as the opening around the pipe is kept as tight as possible, essentially:
  - Cast Iron / Copper / Steel pipes/conduits under 160mm Diameter will not require additional H&V insulation, where insulation is already installed by others and is Rockwool compliant this will be sealed around with Mastic, where the insulation cannot be identified a closing seal (such as Pipe Wrap Roll or HE Mastic will be installed to crush the insulation in the event of a fire).
  - Any other Material pipes under 40mm Diameter will not require H&V insulation (if Non-Combustible) nor will they require a closing device (if they are combustible). They will just be sealed tight around the pipe. Where insulation is already installed by others and is Rockwool compliant (H&V Insulation) this will be sealed around, where the insulation cannot be proven to be Fire Resistant a closing seal (such as

Pipe Wrap Roll or HE Mastic will be installed to crush the insulation in the event of a fire)

- Other Significant things to note:
  - Ducts through fire rated walls should already have dampers on them. Where a damper (Both the BSB & ActionAir DWFX-F) do not require any work other than the opening forming in the partition, this will not be recorded on Bolster and will fall outside of the Firas Accreditation. Where a damper requires a specific visit after the damper has been installed (Only where dampers are fitted tight to the soffits), either to install an ablative Batt seal or a gypsum board pattress then these will be recorded through Bolster and will be within the Firas Accreditation. Sparta will include the Damper Types that will require works under this accreditation within this project pack.
  - In the event there are any **combustible pipes** that have insulation on them, this insulation will be cut very locally to allow a fire collar or similar closure device to be installed.
  - Where there are non-combustible and combustible pipes coming through the floor the Combustible pipes should be 200mm away from any other pipes (including other combustible pipes). Non-combustibles can be close to each other but not within 200mm of a combustible.
  - Bends and knuckles/Joints should not be installed within 55mm of the face of the partition/floor that the Service is passing through in order for a closing device to be installed. There may be scope on this in some locations but always better to leave the space than not.
  - Rev 4 (23<sup>rd</sup> June 2023) we have added in the Engineered Judgements from Rockwool to cover the following and these have been added to the appendix section:
    - Unistrut passing through Fire Walls up to 60min Fire Rating
    - SHS Steelwork passing through Fire Walls up to 60min Fire Rating
    - 25mm Continuous Conduit through Fire Walls up to 60min

#### Scope read and understood by Sparta Management:

Name	Position	Signed
Mathew Bates	Director	Hollo
Dave Fordham	Project Manager	Č
Andrei Bagrin	Site Manager	
Simon Jones	Director	



# FIRESTOPPING PROJECT DETAILS

• Vertical Details (Through Walls)

		Matrix of Solutions	s - Through Walls	
	Α	В	C	D
	Dampers	Cable Trays & Baskets	Plastic Pipes and Conduits	Non Combustible Pipes and conduits
Non Fire Rated Walls	Seal up to Ducts that pass through NFR Walls the same as C & D	<ul> <li>* If through Letterbox then 2 layers of 50mm Ablative Batt fitted into formed opening and acoustic mastic both sides of wall; make sure both faces finish flush</li> <li>* If no preformed opening exists then Ablative Batt Pattress fixed to the wall (with screws that penetrate by at least 12mm) and Intumescent Mastic Seal around service</li> </ul>	* If Gap around opening is <10mm t * If Gap around is greater than 10mm then Ablative Batt Pattress fix Intumescent Mastic S * If through a letterbox opening then 2 layers of 50mm Ablative Batt fitt sure both face	hen Acoustic Intumescent Mastic. ed to the wall (with screws that penetrate by at least 12mm) and eal around service ed into formed opening and acoustic mastic both sides of wall; make s finish flush
30-120 min FR Depending on Circumstance	Ducts up to 315mm: These will be BSB Dampers that do not require any sealing to conform to the Manufacturer Install details. Ducts over 315mm: These will be ActionAir DWFX-F Dampers that do not require any sealing to conform to the Manufacturer Install details unless they are being installed tight to soffits. Where theey are tight to soffit please see Detail for Blockwork HERE Detail for Partition HERE Plastic Ductwork over 160mm: Install only of Envirograf WPCS Collar 60min Integrity & Insulation (all preperation of pipework done by others in line with the datasheets, collar supplied FOC)	<ul> <li>Through Letterbox opening:</li> <li>*2 layers of 50mm Ablative Batt fitted into letterboxed opening and acoustic Intumescent mastic to seal services.</li> <li>Cables to be put into bunches of &lt;50mm diameter by M&amp;E.</li> <li>Omm Seperation needed to Aperture or for Cables, Baskets or Trays.</li> <li>As per Detail RWSD-ACB-0101</li> <li>Achieves 120min Integrity &amp; 60min-90min Insulation (Cable Ladder achieves 90min Integrity only).</li> <li>Where there is no Letterbox opening:</li> <li>*Install an Ablative Batt Pattress each side (Cables to be bunched in 50mm bunches by M&amp;E) Acoustic Intumescent Mastic seal to the services. As per detail RWSD-ACB-0201</li> <li>Cables &amp; Tray Achieve 120min Integrity &amp; 60-90min Insulation</li> <li>Ladder Achieves 90min Integrity &amp; 90min Insulation</li> <li>Option 1 up to 60min Locations: *Bunched Cables (not on a tray) up to 100mm overall diameter, where cables are no bigger than 21mm dia. each (Holes must be cut tight or no larger than 10mm annular gap) RWA45 Insulation backing and then Intumescent Acoustic mastic seal, to a depth of 12.5mm, all the way round. As Detail RWSD-AIS-0110</li> <li>Achieves 60min Incegrity &amp; 45min Insulation</li> <li>Option 2 up to 90min Locations (Double Boarded Walls):</li> <li>*Bunched Cables up to 50mm overall diameter (by M&amp;E); Holes must be cut tight or no larger than 10mm annular gap then Intumescent Acoustic mastic seal, to a depth of 25mm, all the way round. If gap exceeds 10mm then multiple visits and backing insulation may be required (additional costs) As Detail RWSD-AIS-0220</li> <li>Achieves 90min Integrity &amp; 60min Insulation</li> </ul>	Plastic pipes up to 40mm can be sealed tight to the wall to meet the requirements of Approved Doc B, Section B3, subsection 10 Through Letterbox opening: * PVC, HDPE & PP 32mm - 160mm Dia. (1.8mm - 14.6mm pipe wall thickness) - 2 layers of 50mm Ablative Batt with a Pipe collar installed to each side of the batt. As detail RWSD-COL-0002 Achieves 120min Integrity & 120min Insulation Maximum Aperture for this should be: 1,200mm x 730mm For cPVC Pipes see detail RWSD-HE-0051 (Max Aperture size 600mm x 400mm) Through Double Boarded Partitions: * Plastic Pipes 40mm - 160mm with <10mm annular gap - install collars providing there is 200mm separation between the next closest firestopped pipe. As Detail RWSD-COL-0001 Achieves 120min Integrity & 120min Insulation * Plastic Pipes 40mm - 160mm with >10mm annular gap or if there is <200mm separation to other service: use 50mm Ablative Batt as a pattress each side and install Firepro Collar. As Detail RWSD-COL-0003 Achieves 120min Integrity & 120min Insulation Maximum Aperture for this should be: 1,200mm x 730mm For cPVC Pipes see detail RWSD-HE-0054 * Plastic Pipes (Uncommon Installs): use Multicollar Slim Collars. In Accordance with their tested data HERE Achieves 120min Integrity & 120min Insulation These can also be installed to Batt within letterbox scenarios	Uninsulated Cast Iron, Copper & Steel Pipes up to 160mm can be sealed tight to the wall or Ablative Batt to meet the requirements of Approved Doc B, Section B3, subsection 10. Insulated Pipes Through Letterbox opening (Where Insulation installed by others is Rockwool H&V section): * Steel pipes to 168mm dia or Copper Pipes 42mm to 108mm diameter insulated with 25mm-40mm H&V Insulation by others - Install Double 50mm Ablative batt in the letterbox opening and then Seal around the H&V insulation with Intumescent Acoustic Sealant. As per detail RWSD-ACB-0101 Achieves 120min Integrity & 90-120min Insulation Rating Maximum Aperture for this should be: 2,600mm x 2,600mm for max 90min rating & 1,200mm x 900mm for 120min rating Insulated Pipes Through Single & Double Boarded Partitions (Where insulation installed by others is Rockwool H&V section): *Steel pipes to 168mm dia or Copper Pipes 42mm to 108mm diameter insulated with 25 - 40mm H&V Insulation by others - Install 50mm Ablative batt as a face fixed pattress and then seal around the H&V with a bead of Acoustic Intumescent sealant. This is needed to both sides of the partition. As per detail RWSD-ACB-0201 25mm H&V will achieve 90min Integrity & 30-60min Insulation Rating 40mm H&V will achieve 120min Integrity & 120min Insulation Rating Maximum Aperture for this should be: 1,000mm x 1,000mm (Batt size 1,200mm x 1,200mm)

		Disclai	mers	
	Α	В	С	D
	Dampers (FD M9 & FD_C)	Cable Trays & Baskets	Plastic Pipes and Conduits	Non Combustible Pipes and conduits
30-60min Fire				Maximum Aperture size when using H&V Insulation through 2 Ablative Batts within Letterbox opening in a min 100mm wide partition is: 2,600mm x 2,600mm for up to 90min Walls 1,200mm x 900mm for 120min Walls
Rated Walls			Maximum Aperture size when using an insulated Fire Sleeve to	waximum Aperture size when using Pipe wrap koli to seal
		If there are no other services going through the opening then the Maximum Aperture sizes will be as follows:	seal a combustible pipe going through 2 layers of Ablative Batt within a letterbox in a min 100mm wide partition is: 900mm x 600mm	an insulated pipe going through 2 Adiative Batts within Letterbox opening in a min 100mm wide partition is: 1,200mm x 730mm
		Maximum Aperture size when cables going through 2 Ablative Batts within Letterbox opening in a min 100mm wide partition is: 2,600mm x 2,600mm for up to 90min Walls 1,200mm x 900mm for 120min Walls Maximum Aperture size when cables going through Face Fixed Ablative Batt to a min 100mm wide partition is:	Maximum Aperture size when using a Pipe Collar to seal a pipe going through an Ablative Batt pattress in a double boarded min 100mm wide partition is: 1,200mm x 730mm Sparta Advised that insulation won't be passing through any fire walls, where the insulation is installed onto the pipe close to	Maximum Aperture size when using H&V Insulation through Face Fixed Ablative Batt to a min 100mm wide partition is: 1,000mm x 1,000mm (This is due to needing a 50mm overlap so batt total coverage will be 1,200mm x 1,200mm) Maximum Aperture size when using Pipe Wrap Roll to seal
		1,000mm x 1,000mm (This is due to needing a 50mm overlap so batt total coverage will be 1,200mm x 1,200mm)	the wall it may need to be removed by Sparta in order for us to install the closing device solution, such as Collar or Batt & Mastic:	an insulated pipe going through Face Fixed Ablative Batt to a min 100mm wide partition is: 1,200mm x 730mm
90 120min Firo		If there are other services such as Non Combustible Pipes with Pipe Wrap Roll or combustible pipe with Insulated Fire Sleeve then the aperture size will be determined by the service that has the smallest maximum aperture size	Bends and Joins should not be installed within 55mm of the face of the partition that the Service is passing through in order for a closing device to be installed	Any Copper Pipes below 42mm need 100mm of spacing to nearest service or to aperture of an opening, this is true in Letterbox and also if its a pattress
Rated Walls				A masonry wall must have letterbox style opening for services as pattress fix gives insufficient ratings for copper pipes
				Where M&E have already installed Rockwool H&V Insulation, this is compatible with our firestop system so we will just seal around.
1				





The information disclosed herein was originated by and is the property of Swegon Air Management Limited (SAML). SAML reserves all patent, proprietary, design, use, sale, manufacturing and reproduction rights thereto. This does not apply to any vendor parts.



# WPCS KIT FOR LARGE PIPES (WPCS/K) FOR PIPES THAT ARE 3mm THICK AND UPWARDS



**Passive Fire Prevention Products** 

**PRODUCT 13** 

Envirograf® have developed a new WPCS kit to protect large PVC/Polypropylene/UPVC pipes up to 900mm in diameter, with a minimum wall thickness of 3mm, in the event of a fire.

In order to protect the pipe, the following steps below must be taken prior to installation of the WPCS collar. The fiberglass and intumescent coating must be applied to the pipe section passing through the wall and each side of the wall to the depth of the selected WPCS collar.

- 1. Fix 2 sheets of fiberglass cut to length with overlap
- 2. Pots of adhesive will be supplied with pots of hardener to add to adhesive. Stir well. Apply adhesive to the pipe, lay over the first sheet of fiberglass. Ensure the fiberglass overlaps by 50-100mm. You can leave to dry for 10 to 20 minutes.
- 3. Apply the rest the adhesive and then lay over the second sheet of fiberglass. Leave to dry until it has gone hard, approximately for 2 hours.
- 4. Then apply three coats of our grey Intumescent coating at 8m<sup>2</sup> per litre per coat. Each coat takes approximately 20 minutes to dry.
- 5. Your sleeve can now be fitted into the wall. Our WPCS fitted to the outside of the pipe on the fire/risk side and screwed to the wall with fixing brackets supplied.

The kit includes:

- WPCS Collar
- 2 layers of fiberglass
- Adhesive with hardener
- Grey intumescent coating

**ALL TESTED TO:** BS EN 1363-3:2009 BS EN 1366-3-2009 EN 13501-2:2004



**400MM - FITTED TO WALL FOR TESTING** 



#### FIRE PERFORMANCE

400mm	2 hours 4 minutes insulation
600mm	1 hour 56 minutes insulation
900mm	1 hour 41 minutes insulation
Integrity 60 m	linutes

Head Office : Intumescent Systems Ltd, Envirograf House, Barfrestone, Dover, Kent, CT15 7JG, United Kingdom Contact our Technical Team for more information: sales@envirograf.com or visit www.envirograf.com





13







Service type		Flexible / (min. 100	Flexible / rigid wall (min. 100mm thick)		Service separation	
		Integrity	Insulation		Aperture	Services
PVC pipes	Ø 32 - 50mm (1.8mm wall thickness)					
	Ø 55 - 63mm (2.3 - 3mm wall thickness)					
	Ø 75 - 82mm (3.1 - 4.8mm wall thickness)					
	Ø 90 - 110mm (4.2 - 7.4mm wall thickness)	120	120	EN	50mm	0mm
	Ø125mm (6mm wall thickness)					
	Ø140mm (6.1 - 7.5mm wall thickness)					
	Ø160mm (6.2 - 9.5mm wall thickness)					
PP pipes	Ø 32 - 50mm (2.9mm wall thickness)					
	Ø 55 - 63mm (2.9-4.4mm wall thickness)				50mm	0mm
	Ø75-82mm (2.8-6.7mm wall thickness)		120	EN		
	Ø 90 - 110mm (2.7 - 10mm wall thickness)	120				
	Ø125mm (3.1mm wall thickness)					
	Ø140mm (3.5 - 8mm wall thickness)					
	Ø160mm (4 - 14.6mm wall thickness)					
PE pipes	Ø 32 - 50mm (2.9mm wall thickness)					
	Ø 55 - 63mm (2.9 - 4.4mm wall thickness)					
	Ø75 - 82mm (2.8-6.7mm wall thickness)					
	Ø 90 - 110mm (2.7 - 10mm wall thickness)	120	120	EN	50mm	0mm
	Ø125mm (3.1mm wall thickness)					
	Ø 140mm (3.9 - 5.8mm wall thickness)					
	Ø 160mm (4.9 - 9.5mm wall thickness)					

#### ROCKWOOL Standard Detail:

Supporting Evidence : UL-EU-01208-CPR

The supporting construction must be capable of achieving the required fire rating of the proposed firestop.

Flexible wall constructions must be installed in accordance with the manufacturer's guidelines with the aperture being fully framed and lined out. The wall construction should be a minimum thickness of 100mm. This detail can also be applied to rigid wall constructions of 100mm minimum thickness.

All service items should be adequately supported both sides of the firestop to ensure that no load is transferred onto the firestop seal.

Refer to relevant product datasheet for further installation guidelines.

These products should only be utilised for applications as outlined in the relevant ROCKWOOL product data sheet and in accordance with the relevant ROCKWOOL Fire Resistance Testing. Additionally the product must be installed in accordance with the current ROCKWOOL guidelines.

For further information please visit <u>www.rockwool.co.uk</u> or contact our Technical Solutions Team on 01656 868490.

Integrity Per	formance:	Insulation Pe	erformance:
12	20 mins	120 m	ins
te	Pence South W t: 01 echnical.solut	DCKW0 bed, Bridgend /ales CF35 61 656 868490 tions@rockwo	DOL , NY pol.co.uk
Drawing Title	•:		
	OLLAR CE		
PIPE C			
PIPE C Ablative	Coated Batt W	/all Aperture	
PIPE C Ablative	Coated Batt W	/all Aperture	
PIPE C Ablative Scale:	Coated Batt W	/all Aperture	2
PIPE C Ablative Scale: Sheet Size:	A3	/all Aperture Date: FEB 22 Drawn By: S. HIRONS	2 Checked By: L. HAM

The published fire ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd, Expert advice should be sought where such applications are contemplated. The information contained in this drawing is believed to be correct at the date of publication, and is based upon tested and certified solutions. The policy of Rockwool Ltd, is one of constant improvement, Installers should be refore ensure that they are working from the latest published drawings and instructions. Whilst Rockwool will endeavour to keep its publications or anendments to the specification of Rockwool products.



Service type		Flexible / (min. 100	rigid wall mm thick)	Test	Service separation	
	· · · · · / ·	Integrity	Insulation	Standard	Aperture	Services
PVC pipes	Ø32 - 50mm (1.8mm wall thickness)					
	Ø 55 - 63mm (2.3 - 3mm wall thickness)					
	Ø75 - 82mm (3.1 - 4.8mm wall thickness)					
	Ø90 - 110mm (4.2 - 7.4mm wall thickness)	120	120	EN	N/A	200mm
	Ø125mm (6mm wall thickness)					
	Ø140mm (6.1 - 7.5mm wall thickness)			1		
	Ø160mm (6.2 - 9.5mm wall thickness)					
PP pipes	Ø32 - 50mm (2.9mm wall thickness)					
	Ø 55 - 63mm (2.9 - 4.4mm wall thickness)		120	EN	N/A	
	Ø75 - 82mm (2.8-6.7mm wall thickness)					200mm
	Ø90 - 110mm (2.7 - 10mm wall thickness)	120				
	Ø125mm (3.1mm wall thickness)					
	Ø140mm (3.5 - 8mm wall thickness)					
	Ø160mm (4 - 14.6mm wall thickness)					
PE pipes	Ø32 - 50mm (2.9mm wall thickness)					
	Ø 55 - 63mm (2.9- 4.4mm wall thickness)					
	Ø75 - 82mm (2.8-6.7mm wall thickness)					
	Ø90 - 110mm (2.7 - 10mm wall thickness)	120	120	EN	N/A	200mm
	Ø125mm (3.1mm wall thickness)					
	Ø140mm (3.9 - 5.8mm wall thickness)					
	Ø160mm (4.9 - 9.5mm wall thickness)					

#### **ROCKWOOL Standard Detail:**

Supporting Evidence : UL-EU-01205-CPR

The supporting construction must be capable of achieving the required fire rating of the proposed firestop.

Flexible wall constructions must be installed in accordance with the manufacturer's guidelines. The wall construction should be a minimum thickness of 100mm. This detail can also be applied to rigid wall constructions of 100mm minimum thickness.

All service items should be adequately supported both sides of the firestop to ensure that no load is transferred onto the firestop seal.

Refer to relevant product datasheet for further installation guidelines.

These products should only be utilised for applications as outlined in the relevant ROCKWOOL product data sheet and in accordance with the relevant ROCKWOOL Fire Resistance Testing. Additionally the product must be installed in accordance with the current ROCKWOOL guidelines.

For further information please visit www.rockwool.co.uk or contact our Technical Solutions Team on 01656 868490.

Insulation Performance:

.....

Integrity Performance:

	120 mins	120 m	nins					
Pencoed, Bridgend, South Wales CF35 6NY t: 01656 868490								
	technical.soluti	ons@rockw	ool.co.uk					
Drawing	g Title:							
PIP	E COLLAR CE							
Dire	ect Through Wall							
Scale:	NTS	Date: FEB 2	2					
Sheet S	Bize:	Drawn By:	Checked By:					
	A3	S. HIRONS	L. HAM					
Drawing	g Number: RWSD-COL-0001		Revision: C					

The published file ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd, does not accept responsibility for the consequences of using Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advice should be sought where such applications are contemplated. The information contained in his drawing is believed to be correct at the date of publication, and will based upon actified and writing to accept responsibility for the consequences of using Ltd. is one of constaint (mprovement). Installers should thereion ensures of the information contained with his drawing and believed to heave the law accept of the information contained with his drawing and believed to heave the law accept of the publications. regulatory requirements and alterations or amendments to the specification of Rockwool products.





• Ø32 - 160mm pipes · PE, PVC, and PP pipes · Fixed to batt with 80mm long steel pig tail screws through each fixing

 Pipe Collar CE must match the outside diameter of the pipe (e.o. Ø110mm Pipe Collar CE can only be used with Ø110mm pipes)

#### ROCKWOOL FIREPRO® 50mm Ablative Coated Batt

 50mm thickness
 Installed In 1no, face-fixed layer to both sides of the aperture • max. 1200mm x 730mm aperture · Fixed to substrate with 80mm non-combustible screws with 25mm washer at max. 300mm centres Ablative Coated Batt should overlap the aperture by min. 50mm · Edges of the batt to be buttered with Acoustic Intumescent Sealant All batt-to-batt and batt-to-substrate joints to be sealed with Acoustic Intumescent Sealant

Service type		Flexible / (min. 100	Flexible / rigid wall (min. 100mm thick)		Service separation	
		Integrity	Insulation	Standard	Aperture	Services
PVC pipes	Ø32 - 50mm (1.8mm wall thickness)					
	Ø 55 - 63mm (2.3 - 3mm wall thickness)					
	Ø75 - 82mm (3.1 - 4.8mm wall thickness)					
	Ø90 - 110mm (4.2 - 7.4mm wall thickness)	120	120	EN	50mm	0mm
	Ø125mm (6mm wall thickness)					
	Ø140mm (6.1 - 7.5mm wall thickness)					
	Ø160mm (6.2 - 9.5mm wall thickness)					
PP pipes	Ø 32 - 50mm (2.9mm wall thickness)					
	Ø 55 - 63mm (2.9-4.4mm wall thickness)					
	Ø75 - 82mm (2.8-6.7mm wall thickness)					
	Ø90 - 110mm (2.7 - 10mm wall thickness)	120 120		EN	50mm	0mm
	Ø125mm (3.1mm wall thickness)					
	Ø140mm (3.5 - 8mm wall thickness)					
	Ø160mm (4 - 14.6mm wall thickness)					
PE pipes	Ø32 - 50mm (2.9mm wall thickness)					
	Ø 55 - 63mm (2.9-4.4mm wall thickness)					
	Ø75 - 82mm (2.8-6.7mm wall thickness)					0mm
	Ø90 - 110mm (2.7 - 10mm wall thickness)	120	120	EN	50mm	
	Ø125mm (3.1mm wall thickness)					
	Ø140mm (3.9 - 5.8mm wall thickness)					
	Ø160mm (4.9 - 9.5mm wall thickness)					1

#### **ROCKWOOL Standard Detail:**

Supporting Evidence : UL-EU-01208-CPR

The supporting construction must be capable of achieving the required fire rating of the proposed firestop.

Flexible wall constructions must be installed in accordance with the manufacturer's guidelines. The wall construction should be a minimum thickness of 100mm. This detail can also be applied to rigid wall constructions of 100mm minimum thickness.

All service items should be adequately supported both sides of the firestop to ensure that no load is transferred onto the firestop seal.

Refer to relevant product datasheet for further installation guidelines.

These products should only be utilised for applications as outlined in the relevant ROCKWOOL product data sheet and in accordance with the relevant ROCKWOOL Fire Resistance Testing. Additionally the product must be installed in accordance with the current ROCKWOOL auidelines.

For further information please visit www.rockwool.co.uk or contact our Technical Solutions Team on 01656 868490.

Insulation Performance:

120 mins

Integrity Performance:

120 mins

		<b>Ø 10 - 110 mm (4.2</b> - 7.4 mm wan tintkriess) <b>Ø 125 mm (</b> 6mm wall thickness) <b>Ø 140 mm (6.1</b> - 7.5 mm wall thickness) <b>Ø 160 mm (6.2</b> - 9.5 mm wall thickness)	120	120	LIN	301111	Unin				
	PP pipes	Ø32 - 50mm (2.9mm wall thickness)           Ø55 - 63mm (2.9- 4.4mm wall thickness)           Ø75 - 82mm (2.8- 6.7mm wall thickness)           Ø90 - 110mm (2.7 - 10mm wall thickness)           Ø125mm (3.1mm wall thickness)           Ø140mm (3.5 - 8mm wall thickness)           Ø160mm (4 - 14.6mm wall thickness)	120	120	EN	50mm	0mm		Pence South V t: 0 <sup>-</sup> technical.solu	DCKWC Ded, Bridgend, Vales CF35 6N 1656 868490 Itions@rockwo	Y Dl.co.uk
	PEpipes	Ø 32 - 50mm (2.9mm wall thickness) Ø 55 - 63mm (2.9- 4.4mm wall thickness) Ø 75 - 82mm (2.8- 6.7mm wall thickness) Ø 90 - 110mm (2.7 - 10mm wall thickness) Ø 125mm (3.1mm wall thickness) Ø 140mm (3.9 - 5.8mm wall thickness) Ø 160mm (4.9 - 9.5mm wall thickness)	120	120	EN	50mm	0mm		Drawing Title: PIPE COLLAR CE Face-fix Ablative Coat	ed Batt	
The published fire ratings have been achieved by Rockwool products in applications or for purposes Ltd, is one of constant improvement, Installers as mend-	ollowing the Instructions set out above. Use of alternation of authorities of the Advice should be refore ensure that they are working from the la advice its the encertaintee of Reckued required.	itive components or deviations from the instructions in any way is likely to mean that the be sought where such applications are contemplated. The information contained in this lest published drawings and instructions. Whilst Rockwool will endeavour to keep its pu	e installation will not s drawing is believed ublications up to dat	comply with the ass d to be correct at the e the accuracy of th	sessed rating. Roo a date of publicatio e information cont	skwool Ltd. does not n, and is based upor alned within this draw	accept responsibility n tested and certified wing may be affected	r for the consequences of using solutions. The policy of Rockwool I by pertinent changes in the law or	NTS Sheet Size: - A3 Drawing Number: RWSD-COL-00	Drawn By: S. HIRONS	Checked By: L. HAM Revision: C

regulatory requirements and alterations or amendments to the specification of Rockwool products.





The information disclosed herein was originated by and is the property of Swegon Air Management Limited (SAML). SAML reserves all patent, proprietary, design, use, sale, manufacturing and reproduction rights thereto. This does not apply to any vendor parts.

## Actionair DWFX-F Installation Guide



# Vertical Damper Installation in a Plasterboard Wall

Actionair SmokeShield PTC - [AA/F10704] Actionair FireShield - [AA/F10705]

#### **Installation Method**

- 1. Measure the overall Fire damper casing size w x h, but for Smoke Shield include the PTC Shroud (28mm) in the width but do not include any of the peripheral flange.
- 2. Calculate the hole size using hole sizer program available on www.swegon.com/uk
- 3. For Fire Shield calculate the finished hole size by adding 10-40mm to the case width and height.
- 4. For Smoke Shield calculate the finished hole size adding 10-52mm to the width and 10-40mm to the height.
- 5. Calculate the hole to cut size by adding two board thicknesses to the finished hole width and height.
- 6. Mark out the hole on the partition and cut it out, cutting the top and bottom edges first to maintain stability.
- 7. Frame out the hole with stud and track and cover this with board. Finish edges with joint filler.
- 8. Drill clearance holes in the damper flange at 150mm centres and such that they will allow screws to pull into

the stud and track around the hole.

- 9. Install the damper and fasten.
- 10. Back fill and complete penetration seal as per the installation drawing
- 11. Connecting ductwork omitted for clarity. Ductwork must be independently supported. There must be an appropriate break-away joint between the damper and connecting ductwork on both sides of assembly. Aluminium rivets or plastic cleats, clips, clamps and bolts etc. should be used for this, unless fire resisting ductwork is being used where fire resisting fixings should be used. A minimum of 200 mm between fire dampers installed in separate ducts and 75 mm between fire damper and a construction element (wall/floor).



## Actionair DWFX-F Installation Guide



Vertical Damper Installation in a Masonry Wall

Actionair SmokeShield PTC - [AA/F12493] Actionair FireShield - [AA/F10707]

#### Installation Method

- 1. Drill clearance holes in the damper flange at 150mm centres.
- 2. Install the damper and fix through flange using fire rated fasteners, min ø4mm.
- 3. Back fill and complete penetration seal as per the installation drawing
- 4. Connecting ductwork omitted for clarity. Ductwork must be independently supported. There must be an appropriate break-away joint between the damper and connecting ductwork on both sides of assembly. Aluminium rivets or plastic cleats, clips, clamps and bolts etc. should be used for this, unless fire resisting duct-work is being used where fire resisting fixings should be used. A minimum of 200 mm between fire dampers installed in separate ducts and 75 mm between fire damper and a construction element (wall/ floor).

actionair<sup>®</sup>



#### FD-C in Dry Wall

#### Tested to BS EN 1366-2

The FD-C series damper has been tested both ways, with access side inside the furnace and non-furnace side

#### **Test Conclusions:**

The FD-C damper satisfied the requirements of BS EN 1366-2 and BS EN 13501-3.

Dampers were tested from both sides of the furnace wall.

The FD-C single blade combination fire and volume control damper with its unique feature of requiring only a single installation plate when being installed within tested applications, and without the need for any infill between the damper body and the structure that it sits within.

#### VIEW FROM NON-FURNACE SIDE

- Tested to BS EN 1366-2 and classified to BS EN 13501-3
- ES90 integrity and leakage classification.
- Complies with classes A, B & C of DW144.
- Fire and Volume Control dual function





#### FD-C in Blockwork Wall

#### Tested to BS EN 1366-2

The FD-C series damper has been tested both ways, with access side inside the furnace and non-furnace side.

#### **Test Conclusions:**

The FD-C damper satisfied the requirements of BS EN 1366-2 and BS EN 13501-3.

Dampers were tested affixed to the non furnace side of the furnace wall with the damper closed blade being fully exposed to the furnace rapid rising temperature.

The achieved ES classification ensures that in a fire condition the non fire side is fully protected (from radiated heat) for the achieved period, providing vital time for the emergency services to respond, ensuring safe passage of escape and protection of contents.

- Tested to BS EN 1366-2 and classified to BS EN 13501-3
- DW145 Method 4 refers
- ES120 integrity and leakage classification
- Complies with classes A, B & C of DW144 and BS EN 1751
- Fire and Volume Control dual function









regulatory reguirements and alterations or amendments to the specification of Rockwool products

RWSD-HF-0111

#### **Joint Sealings in Coated Batts**

Coated batts can be used in combination with flexible walls, rigid walls and rigid floors. The fire barriers must have a minimum thickness of 100 mm (2x50 mm), with a density of at least  $\geq$  ~ 150 kg/m<sup>3</sup>.

Joints around service penetrations, with or without insulation, must have a fire-resistant seal to prevent the passage of smoke and hot gases. Multimastic SP fire stopping mastic should be used for this purpose. When the ducts are completely enclosed by fire-stopping rock wool, fire stopping mastic is not required. For more information, see ETA report 17/0836



Permissible filling materials for joints around pipe penetrations
Multimastic SP, fire stopping mastic
Joint width: ≤ 20 mm
Depth: ≥ 10 mm, on both sides of the wall

## 4. Tested Configurations

#### **Plastic Pipes, Uninsulated**

Construction	Thickness [mm]	Configuration*	Max. Ø [mm]	Insulation type
		Straight pipes	Ø 315	
		Inclined pipes $\ge 45^{\circ} - 90^{\circ}$		
		Coupling elements	Ø 125	
Rigid and flexible walls	≥ 100	87° / 90° Elbows		
		Elbow 2 x 45°	<b>G</b> 440	
		Corner solutions	Ø 110	n/a
		Support structure	Ø 90	
		Multiple penetrations	Ø 75 (3x)	
		Straight pipes	Ø 315	
	> 450	Inclined pipes $\ge 45^{\circ} - 90^{\circ}$	Ø 125	
Pigid floors		Coupling elements	0125	
Rigid hoors	2 150	Elbow 2 x 45°	Ø 110	
		Corner solutions	Ø 110	
		Multiple penetrations	G 440	
Rock wool coated batts	≥ 2 x 50	Straight pipes	Ø 110	

\*see the "Tested configurations" table on page 14 and 15





MULCOL





### 5. Installation Manual Multicollar Slim



Make sure that the service penetration and the gap are free from dust, dirt and grease.



Cut the inlay away with the knife on both sides of the custom-size fire collar.



Openings  $\leq$  20 mm<sup>1</sup> can be sealed with Multisealent A firestop acrylic sealant or Multimastic SP firestop mastic, over a depth of 10 mm.



If the stainless-steel joints fit well together, the inlay has been properly cut.



Measure the diameter of the service penetration. See the application table on the packaging (for plastic pipes 2) for the lenght of Multicollar *Slim* (number of segments) and the multiclips required.



Place the fire collar around the service penetration, attach the end of the fire collar with multiclip and secure with the screws provided.



Count the number of Multicollar *Slim* segments required on the roll and then cut through the inlay with a knife.



Distribute the remaining Multiclips proportionally and secure with screws.



Break the Multicollar *Slim* where it has been cut.



Fill in the conformity statement and paste it next to the fireproof seal.

- <sup>1</sup>Larger openings around service penetrations can be sealed according to the installation requirements for the Multimastic C System or the Multimortar System.
- <sup>2)</sup>Steel pipes with insulation, depending on the fire resistance, can be provided with a single fire collar up to a total diameter of 283 mm.



![](_page_27_Picture_24.jpeg)

For use and for more information about an application, refer to the Mulcol documentation, local and international approvals.

See the **Mulcol Fire Protection app** for the correct application in combination with fire resistance, or use **our selector at www.mulcol.com** For professional use only.

![](_page_27_Picture_27.jpeg)

### 6. Performance

#### Uninsulated Plastic Pipe Penetrations through Flexible Walls, Rigid Walls and Floors

EN 1366-3

PVC-U / PVC-C pipes	Seal size Ø x s [mm]	<b>Multico</b> l Single	<b>llar <i>Slim</i></b> Dual	Assembly side(s)	Spacing	<b>C</b> 4 FW-100	onstructio RW-100	<b>n</b> RF-150	Classificatie minutes
	≤ 110 x 1,8 - 14,6	~							≤ EI 90-U/U
	≤ 160 x 1,8 - 14,6			2	- fig. 1 to 4 -	~	~		≤ EI 120-U/U
<b>C</b> L <b>: : : :</b>	≤ 315 x 1,8 - 14,6								≤ EI 90-U/C
Straight pipes	≤ 110 x 1,8 - 14,6								≤ EI 90-U/U
	≤ 160 x 1,8 - 14,6			1				<b>~</b>	≤ EI 120-U/C
	≤ 315 x 1,8 - 14,6		~						≤ EI 120-U/C
Inclined pipes	≤ 110 x 3,4 - 10,0								≤ EI 60-U/C
	≤ 110 x 3,4		~						≤ EI 120-U/C
	≤ 110 x 2,7			2	fig. 1 to 4				≤ EI 45-U/C
≥ 45° - 90°	≤ 125 x 2,5	~							≤ EI 30-U/C
	≤ 110 x 3,4 - 10,0		~						≤ EI 60-U/U
	≤ 110 x 10,0							<b>`</b>	≤ EI 90-U/U
87° / 90° Elbows	≤ 125 x 2,5	~		2	fig. 1 to 4	<ul> <li></li> </ul>	<ul> <li></li> </ul>		≤ EI 90-U/U
87° / 90° Elbows,	< 110 × 2.4				6 AL A				< EL120 LU/C
zero distance to wall	≤ 110 x 3,4			2	tig. 1 to 4				≤ EI 120-0/C
Elbow 2 x 45° ,	≤ 50 x 3,0				6 AL A				≤ EI 90-U/C
zero distance to floor	≤ 110 x 3,2			1	fig. 1 to 4			<b>`</b>	≤ EI 45-U/C
	≤ 110 x 2,2 - 2,3					~	<ul> <li></li> </ul>		≤ EI 90-U/U
Corner solutions	≤ 110 x 6,3			1	fig. 1 to 4			<b>~</b>	≤ EI 90-U/U
	≤ 125 x 7,4								≤ EI 60-U/C
Zero distance to floor	≤ 110 x 2,2	~		1	fig. 1 to 4			~	≤ EI 90-U/U

PP pipes	Seal size Ø x s [mm]	<b>Multico</b> l Single	<b>llar <i>Slim</i></b> Dual	Assembly side(s)	Spacing	<b>Cc</b> FW-100	RW-100	<b>n</b> RF-150	Classification minutes
	≤ 110 x 1,8 - 6,3			2					≤ EI 120-U/U
	≤ 125 x 1,8 - 7,1								≤ EI 90-U/U
	≤ 125 x 1,8 - 3,1					~	~		≤ EI 120-U/U
	≤ 160 x 1,8 - 4,0								≤ EI 90-U/U
Straight pipes	≤ 160 x 9,1	~	1	fig. 1 to 4				≤ EI 120-U/C	
	≤ 40 x 1,8 - 6,3								≤ EI 120-U/U
	≤ 110 x 1,8 - 3,6			1				~	≤ EI 90-U/U
	≤ 125 x 1,8 - 4,8								≤ EI 60-U/U
	≤ 160 x 1,8 - 14,6								≤ EI 90-U/C
	≤ 110 × 3,4 - 10,0			2					≤ EI 60-U/C
Inclined hines	≤ 110 × 3,4		~	2		~	~		≤ EI 120-U/C
> 4F° 00°	≤ 110 × 2,7	<			fig. 1 to 4				≤ EI 45-U/C
≥ 45 - 90	≤ 110 × 3,4 - 10,0			4					≤ EI 60-U/U
	≤ 110 × 10,0		~	1					≤ EI 90-U/U
87° / 90° Elbows	≤ 125 x 3,1	<ul> <li>Image: A start of the start of</li></ul>		2	fig. 1 to 4	<ul> <li>Image: A start of the start of</li></ul>	<ul> <li></li> </ul>		≤ EI 90-U/C
Corner solutions	≤ 110 x 6,3	<ul> <li>Image: A second s</li></ul>		1	fig. 1 to 4			~	≤ EI 90-U/U

E: I:

Integrity Thermal insulation

 $\emptyset \times S[mm]$  Diameter x wall thickness of the penetration

FW-100: RW-100: RF-150:

Flexible wall, 100 mm thick Rigid wall, 100 mm thick Rigid floor, 150 mm thick

![](_page_28_Picture_10.jpeg)

#### EN 1366-3

PE / PE-HD / ABS / SAN+PVC pipes	Seal size Ø x s [mm]	<b>Multico</b> Single	<b>llar <i>Slim</i></b> Dual	Assembly side(s)	Spacing	<b>C</b> a FW-100	RW-100	<b>n</b> RF-150	Classification minutes
	≤ 110 x 2,4 - 10,0								≤ EI 60-U/U
	≤ 125 x 2,4 - 4,0			2		~	<b>~</b>		≤ EI 90-U/U
	≤ 125 x 2,4 - 4,9				fig. 1 to 4				≤ EI 120-U/U
Straight pipes	≤ 110 x 2,4 - 6,6	<ul> <li>✓</li> </ul>							≤ EI 120-U/U
	≤ 125 x 2,4 - 4,9							~	≤ EI 90-U/U
	≤ 160 x 2,4 - 4,0			'					≤ EI 60-U/U
	≤ 160 x 14,6								≤ EI 120-U/C
Inclined sizes	≤ 110 x 2,7	~		2					≤ EI 60-U/C
	≤ 110 x 3,4 - 10,0		<		fig. 1 to 4	×			≤ EI 120-U/C
≥45 -90	≤ 110 x 10,0			1				~	≤ EI 90-U/U
Metal supp. half shell	≤ 90 x 2,8	~		2	fig. 1 to 4	~	~		≤ EI 90-U/C
Zero distance to floor	≤ 110 x 2,8	~		1	fig. 1 to 4			<	≤ EI 90-U/U
Corner solutions	≤ 110 x 6,6	~		1	fig. 1 to 4			~	≤ EI 120-U/U
	≤ 110 x 4,3 - 7,4								≤ EI 60-U/C
	≤ 110 x 4,3			2	fig 1 to 1	×			≤ EI 120-U/C
Coupling elements	≤ 110 x 4,3				iig. i to 4				≤ EI 90-U/C
	≤ 125 x 7,4			1				<b>`</b>	≤ EI 60-U/C

Low noise pipes <sup>(1)</sup>	Seal size Ø x s [mm]	<b>Multico</b> Single	<b>llar <i>Slim</i></b> Dual	Assembly side(s)	Spacing	<b>Co</b> FW-100	RW-100	<b>n</b> RF-150	Classification minutes
Elbow 2 x 45°,	≤ 110 x 3,6			2	fig. 1 to 4				≤ EI 60-U/U
Zero distance to wall	≤ 110 x 6,0	<b>`</b>		2	lig. 1 to 4	•	<b>`</b>		≤ EI 90-U/U
Elbow 2 x 45°,	≤ 110 x 6,0			1	fig. 1 to 4			~	≤ EI 90-U/U
Zero distance to floor	≤ 110 x 5,3								≤ EI 120-U/U
Corner solutions,	< 110 × 6.0			2	fig. 1 to 4				
zero distance to ceiling	≤ 110 x 6,0	Ň		2	iig. 1 to 4	•			≤ EI 60-0/0
Corner solutions,	< 110 ··· C O			2	fig 1 to 1				
zero distance to floor	≤ 110 x 6,0	<b>`</b>		2	lig. 1 to 4	~	~		≤ EI 120-0/0
Corner solutions	≤ 110 x 6,6	~		1	fig. 1 to 4			~	≤ EI 120-U/C
Coupling elements	≤ 110 x 2,7	~		2	fig. 1 to 4	~	~		≤ EI 120-U/C
Courdline along anto	≤ 110 x 6,3			1	fig. 1 to 4			~	≤ EI 90-U/U
	≤ 110 x 2,7 - 6,0	<b>`</b>							≤ EI 120-U/C

<sup>(1)</sup> Permitted low noise pipes - Coes PhoNoFire

- Coestilen BluePower - Geberit Silent dB20

- Geberit Silent dB20 - Geberit Silent PP - Girpi Friaphon - Marley Silent - Pipelife Master 3 - PhonEX AS - Poloplast POLO-KAL NG - Poloplast POLO-KAL 3S - REHAU Raupiano Plus - Skolan dB

- KEHAO Kuupia - Skolan dB - Valsir Triplus - Wavin AS - Wavin SiTech+ - DykaSono

E: I:

Integrity Thermal insulation

FW-100:	Flexible wall, 100 mm thick
RW-100:	Rigid wall, 100 mm thick
RF-150:	Rigid floor, 150 mm thick

Ø x S [mm]: Diameter x wall thickness of the penetration

![](_page_29_Picture_22.jpeg)

![](_page_30_Picture_0.jpeg)

# FIRESTOPPING PROJECT DETAILS

• Horizontal Details (Through Floors)

#### Firestopping Matrix - Through Floors

	Dampers	Cable Trays & Baskets	Plastic Pipes and Conduits	Non Combustible Pipes and conduits		
Non Fire Rated	N/A		N/A			
60min Fire Rated	To be discussed and designed separately, Installed in line with Damper Manufacturers Test detail or Separate Agreements	50mm Batt as shuttering tight to the service then trowell on the first 25mm of Compound, allow to cure and then install the remaining 75mm of compound. As detail RWSD- COM-0501 Achieves 120min Integrity & 60min Insulation (Cables should be bunched by M&E and no larger than 100mm)	For Oversized Concrete Openings Option 1: * 40mm - 160mm Dia. PVC, PP & PE Pipes: Install 2 layers of 50mm Batt in the with edges and cuts coated with Acoustic Intumescent Sealant and then sealed at edges with a bead of the same. Then install a Pipe Collar CE suitable for the pipe with 80mm long pig tail fixings into the batt. As Detail RWSD-COL-0503 Achieves 120min Integrity & 120min Insulation Rockwool Compound can be added to the top side of this detail to bring finish flush with floor level but must be installed as a separate install (Email from Ryan at Rockwool 29/03/21) and will not conform to the compound loadings unless the compound is min 75mm thick For Oversized Concrete Openings Option 2: *40mm - 160mm Dia.PVC, PP & PE Pipes; Install centrally within the opening an Insulated Fire Sleeve to suit pipe size, then fill the 150mm depth of the opening with Fire Compound as long as the gap is greater than 15mm. May need shuttering batt from underside. As detail RWSD- IFS-0601 Achieves 120min Integrity & 60min - 120min Insulation (Ensure that pipe wall thicknesses are observed as per table on detail) For Tight(ish) Concrete Openings: *40mm - 160mm Dia.PVC, PP & PE Pipes (Ensure there is 200mm Service seperation and that pipe wall thicknesses are observed as per table on detail): Install FirePro Pipe Collar fixed from underside. As Detail RWSD-COL- 0501 (<10mm gaps can be sealed around the pipe with Acoustic Intumescent Sealant, 11mm - 50mm gaps must be filled with Compound through the full depth of the floor) Achieves 120min Integrity & 120min Insulation	<ul> <li>For oversized openings (Pipes lagged with Rockwool H&amp;V):</li> <li>* Steel Pipes up to 165mm Diameter and Copper Pipes up to 108mm Diameter; Install</li> <li>Somm Batt as shuttering tight to the services then trowell on the first 25mm of</li> <li>Compound, allow to cure and then install the remaining 75mm of compound. As detail</li> <li>RWSD-COM-0501 or RWSD-COM-0503</li> <li>Achieves 120min Integrity &amp; 120min Insulation rating if Pipes are insulated with 40mm</li> <li>Rockwool H&amp;V Section and have spacing, if they are clustered together Copper Pipes</li> <li>will only achieve 45min Insulation Rating.</li> <li>For oversized openings (Where they pass through the same opening as a Combustible Pipe):</li> <li>* The solution installed for the plastic pipe will protect the plastic pipe in the first instance but will also protect the non combustible going through the same constuction as long as spacings are given between pipes as advised, the non combustible pipes can be mastic sealed on underside to keep neat or compounded on top side.</li> <li>Consider Detail RWSD-ACB-0501</li> <li>Achieves up to 120min Integrity &amp; 90min Insulation when insulated with min 25mm H&amp;V) (No Insulation rating if not lagged)</li> <li>For Tight Concrete Openings:</li> <li>*Steel Pipes up to 159mm Diameter and Copper Pipes up to 108mm Diameter: No works required as no gap to seal, in the event there is a small gap up to 5mm then seal above and below with Acoustic Intumescent Mastic.</li> <li>Achieves 60min Integrity (Insulation rating not required on these size pipes)</li> </ul>		

			Disclaimers	
	Α	В	С	D
	Dampers (FD M9 & FD_C)	Cable Trays & Baskets	Plastic Pipes and Conduits	Non Combustible Pipes and conduits
ALL	* 75mm or 1 * 100mm de * Larger ape	00mm depth of compoun pth of compound can be 7 rtures will need to be rein	d the can be 500mm wide x any length install 100mm where poss 50mm x 750mm aperture forced compound and will carry additional charges. These can be	sible as this works better for 0mm seperation with H&V insulated pipes up to 1,500mm wide by any length
60min Fire Rated Floors			M&E have advised they are not insulating pipes through floors, if they are the insulation will be removed locally and the closing device set out in the solutions would be used Combustible pipes must not have joints or bends within 55mm of the surface they are passing through, in order to allow sufficient room for a closing device solution to be installed	Any pipes insulated with anything that isn't H&V insulated will either need insulation removing completely or removing and insulating with H&V insulation. If in doubt what thickness of H&V to use then go with 40mm H&V, otherwise ask the question

#### INSTALLATION NOTES

A permanent shuttering made from 50mm ROCKWOOL slab (minimum density 140kg/m3) is cut and friction fitted between services and the edges of the floor slab. Firestop Compound is then trowelled over the shutter to a depth of 25mm thick. This is allowed to cure. Further Firestop Compound is then mixed to a pouring grade and tops the seal up to the required depth.

#### Floor openings

1) A bag of compound to 10 litres water (3:1) by volume. Vary to suit site conditions

2) Set the shuttering into the opening ensuring a tight fit so that once the required depth of Compound is installed it finishes flush with the floor slab/screed unless otherwise specified

3) Mix and pour compound until the required thickness is achieved.

#### Reinforcement

Reinforcing of the compound requires either 12mm diameter bars or 40mm (high) x 60mm steel angle fixed across the short span of the aperture. The bars should be installed at 200mm centres across the aperture and may be installed such that they are recessed into the surrounding structure by minimum 50mm on both sides or supported on an steel angle securely fixed to the structure.

Steel angle reinforcement shall be installed at 250mm centres and shall be bolted back to supporting angle, which is fixed back to the structure. The support angle for rod or angle reinforcement shall be 50mm x 50mm x 1.6mm and shall be securely fixed back to the structure with nominally 8mm steel anchor bolts at a maximum of 200mm centres.

In all instances the reinforcement shall be positioned approximately 30mm above the bottom surface of the compound to ensure adequate fire protection from below.

![](_page_33_Figure_10.jpeg)

120 Mi

90 Minutes

	fc a T	or single Pipe pplications co echnical Solu	Wrap CE ontact ROCKWOOL utions	insta guid <u>www</u> Tear	stance Testing, Addition, lled in accordance with t elines. For further inform <u>.rockwool.co.uk</u> or conta n on 01656 868490.	any the product must be he current ROCKWOOL ation please visit act our Technical Solutic
				Integrit	y Performance:	Insulation Performance:
utes Insulation	240 N Integrity	Ainutes Insulation			Up to 240 minutes	Up to 240 minutes
* * *	√ √	* *				KWOOL
	✓ ✓ ✓ ✓				Pencoed, South Wale t: 01656 technical.solution	Bridgend, s CF35 6NY s 868490 s@rockwool.co.uk
✓ ✓	✓ ✓			Drawin	ig Title:	
				i ⊢ira		

#### **ROCKWOOL Standard Detail:**

Supporting Evidence : BMTFEIF14015 / WF 518225 WF 436617 / WF 389239 / WF 518794

The supporting construction must be capable of achieving the required fire rating of the proposed Firestop.

All service items should be adequately supported either side of the Firestop to ensure that no permanent load is transferred onto the coated batt.

The Firestop compound is designed to accommodate light foot traffic in line with BS6399 for workspaces and cupboards.

Combustible pipes passing through the compound shall be provided with either ROCKWOOL Firestop Collar or Wrap. It is important to ensure that the collar or wrap shall remain exposed at the soffit (therefore to direct fire exposure). If the shuttering batt is to remain in place then care shall be taken to ensure the intumescent device remains exposed. One option to achieve this would be to use a PE backing rod between the pipe and the batt to ensure the shuttering allows the compound to be poured yet burns away quickly to expose the intumescent. A width of 15mm is suggested.

These products should only be utilised for applications as outlined in the relevant ROCKWOOL product data sheet and in accordance with the relevant ROCKWOOL Fire duct must be ROCKWOOL se visit hnical Solutions

Service type	Integrity	Insulation	Integrity	Insulation	Integrity	Insulation	Integrity	Insulatio
75mm Blank seal up to 500 mm x 500 mm*	~	~	~	~	~	~		
100mm Blank seal up to 750 mm x 750 mm*	~	~	~	~	~	~	~	~
75mm Seal with services no reinforcement - 500mm x any length*	~	~	~	~	~	✓		
100mm Seal with services, Simply Reinforced - 1500mm x any length*	~	~	~	~	~	✓	~	~
Cable Tray ≤500mm x 50mm	~	~	~	~	~		~	
Bunched cables ≤100 mm	~	~	~		~			
Electrical cables up to 21mm	~	~	~	~	~		~	
Electrical cables 21mm - 50mm	~	~	~		~		~	
Electrical cables 51mm - 80mm	~		~		~		~	
Steel pipes ≤165 Unlagged	~		~		~		✓	
Steel pipes ≤165 lagged with Fire Tube	~	~	~	~	~	✓	~	
Copper pipes≤108 mm lagged with Fire Tube	~	~	~	~	~	✓	~	
Copper pipes ≤ 108 mm unlagged	~		~		~		~	
<160mm PVC, uPVC, PP, MDPE & HDPE pipe Rockwool Pipe Wrap	~	~	~	~	~	~		
* Load bearing performance in line with BS6399 for workspaces and cupboards								

Drawing Title	:		
FireStop Floor Se	Copound al		
Scale:	NTS	Date: AUG	22
Sheet Size:	A3	Drawn By: RW TECH	Checked By: L.HAM
Drawing Num	ber:		Revision:

The published file ratings have been achieved by following the Instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the Installation will not comply with the assessed rating. Rockwool Ltd, does not accept responsibility for the consequences of Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advice should be sought where such applications are contemplated. The Information contained in this drawing is believed to be correct at the date of publication, and is based upon tested and certified solutions. The policy of I Ltd, is one of constant improvement. Installers should therefore ensure that they are working from the latest published drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this drawing may be affected by pertinent changes in regulatory requirements and alterations or amendments to the specification of Rockwool products.

![](_page_34_Figure_0.jpeg)

· Pipe Collar CE must match the outside diameter of the pipe (e.g. Ø110mm Pipe Collar CE can only be used with Ø110mm pipes)

PVC pipes	PP pipes	PE pipes	Integrity	Insulation
Ø 32mm (1.8mm wall thickness)	Ø 32mm (2.9mm wall thickness)	Ø 32mm (2.9mm wall thickness)		
Ø 40mm (1.8mm wall thickness)	Ø 40mm (2.9mm wall thickness)	Ø 40mm (2.9mm wall thickness)		
Ø 50mm (1.8mm wall thickness)	Ø 50mm (2.9mm wall thickness)	Ø 50mm (2.9mm wall thickness)		
Ø 55mm (2.3 - 2.8mm wall thickness)	Ø 55mm (2.9- 4.4mm wall thickness)	Ø 55mm (2.9- 4.4mm wall thickness)		
Ø 63mm (2.3 - 2.8mm wall thickness)	Ø 63mm (2.9- 4.4mm wall thickness)	Ø 63mm (2.9- 4.4mm wall thickness)		
Ø 75mm (3.1 - 4.4mm wall thickness)	Ø 75mm (2.8- 6.7mm wall thickness)	Ø 75mm (2.8- 6.7mm wall thickness)		
Ø 82mm (3.1 - 4.4mm wall thickness)	Ø 82mm (2.8- 6.7mm wall thickness)	Ø 82mm (2.8- 6.7mm wall thickness)	120	120
Ø 90mm (4.2 - 6.6mm wall thickness)	Ø 90mm (2.7 - 10mm wall thickness)	Ø 90mm (2.7 - 10mm wall thickness)		
Ø 100mm (4.2 - 6.6mm wall thickness)	Ø 100mm (2.7 - 10mm wall thickness)	Ø 100mm (2.7 - 10mm wall thickness)		
Ø 110mm (4.2 - 6.6mm wall thickness)	Ø 110mm (2.7 - 10mm wall thickness)	Ø 110mm (2.7 - 10mm wall thickness)		
Ø 125mm (6mm wall thickness)	Ø 125mm (3.1mm wall thickness)	Ø 125mm (3.1mm wall thickness)		
Ø 140mm (6.1 - 7.5mm wall thickness)	Ø 140mm (3.5 - 8mm wall thickness)	Ø 140mm (3.9 - 5.8mm wall thickness)		
Ø 160mm (6.2 - 9.5mm wall thickness)	Ø 160mm (4 - 14.6mm wall thickness)	Ø 160mm (4.9 - 9.5mm wall thickness)		

#### **ROCKWOOL Standard Detail:**

#### Supporting Test Data : XXXXXX The supporting construction must be capable of achieving the required fire rating of the proposed firestop.

All service items should be adequately supported both sides of the firestop to ensure that no load is transferred onto the firestop seal.

Refer to relevant product datasheet for further installation guidelines.

These products should only be utilised for applications as outlined in the relevant ROCKWOOL product data sheet and in accordance with the relevant ROCKWOOL Fire Resistance Testing. Additionally the product must be installed in accordance with the current ROCKWOOL quidelines.

For further information please visit www.rockwool.co.uk or contact our Technical Solutions Team on 01656 868490.

Integrity Performance:	Insulation Performance:
120 mins	120 mins

120 mins

![](_page_34_Picture_12.jpeg)

Pencoed, Bridgend, South Wales CF35 6NY t: 01656 868490 technical.solutions@rockwool.co.uk

Drawing Title:

PIPE COLLAR CE Ablative Coated Batt Floor Aperture

Scale: NTS	Date: SEP 20		
Sheet Size:	Drawn By:	Checked By:	
A3	S. HIRONS	L. HAM	
Drawing Number:	Revision:		
RWSD-COL-050	-		

The published fire ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd. does not accept responsibility for the consequences of using	
Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advice should be sought where such applications are contemplated. The information contained in this drawing is believed to be correct at the date of publication, and is based upon tested and certified solutions. The policy of Rockwool	Dra
Ltd. is one of constant improvement. Installers should therefore ensure that they are working from the latest published drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this drawing may be affected by pertinent changes in the law or	
regulatory requirements and alterations or amendments to the specification of Rockwool products.	

![](_page_35_Figure_0.jpeg)

#### **ROCKWOOL Standard Detail:**

![](_page_36_Figure_1.jpeg)

The supporting construction must be capable of achieving the required fire rating of the proposed firestop.

All service items should be adequately supported both sides of the firestop to ensure that no load is transferred onto the firestop seal.

Refer to relevant product datasheet for further installation guidelines.

These products should only be utilised for applications as outlined in the relevant ROCKWOOL product data sheet and in accordance with the relevant ROCKWOOL Fire Resistance Testing. Additionally the product must be installed in accordance with the current ROCKWOOL guidelines.

For further information please visit <u>www.rockwool.co.uk</u> or contact our Technical Solutions Team on 01656 868490.

ntegrity Performance:	Insulation Performance:
240 mins	240 mins

## 

Pencoed, Bridgend, South Wales CF35 6NY t: 01656 868490 technical.solutions@rockwool.co.uk

Drawing Title:

PIPE COLLAR CE Solid Floor

Scale:	NTS	Date:	SEP 20	
Sheet Size:	A3	Drawn By S. HIR	y: ONS	Checked By: L. HAM
Drawing Num	<sup>ber:</sup> NSD-COL-050 <sup>°</sup>	1		Revision: -

![](_page_36_Figure_13.jpeg)

		Rigid	Rigid floor		Service separation	
	Service type	(min. 150	mm thick)	Standard		sparation
		Integrity Insulation		Standard	Aperture	Services
PVC pipes	Ø 32 - 50mm (1.8mm wall thickness)					
	Ø 55 - 63mm (2.3 - 3mm wall thickness)					
	Ø 75 - 82mm (3.1 - 4.8mm wall thickness)					
	Ø 90 - 110mm (4.2 - 7.4mm wall thickness)	240	240	EN	N/A	200mm
	Ø 125mm (6mm wall thickness)					
	Ø 140mm (6.1 - 7.5mm wall thickness)					
	Ø 160mm (6.2 - 9.5mm wall thickness)					
PP pipes	Ø 32 - 50mm (2.9mm wall thickness)			EN	N/A	200mm
	Ø 55 - 63mm (2.9- 4.4mm wall thickness)					
	Ø 75 - 82mm (2.8- 6.7mm wall thickness)					
	Ø 90 - 110mm (2.7 - 10mm wall thickness)	240	240			
	Ø 125mm (3.1mm wall thickness)					
	Ø 140mm (3.5 - 8mm wall thickness)					
	Ø 160mm (4 - 14.6mm wall thickness)					
PE pipes	Ø 32 - 50mm (2.9mm wall thickness)					
	Ø 55 - 63mm (2.9- 4.4mm wall thickness)				N/A	200mm
	Ø 75 - 82mm (2.8- 6.7mm wall thickness)		240 240	240 EN		
	Ø 90 - 110mm (2.7 - 10mm wall thickness)	240				
	Ø 125mm (3.1mm wall thickness)					
	Ø 140mm (3.9 - 5.8mm wall thickness)					
	Ø 160mm (4.9 - 9.5mm wall thickness)					

The published fire ratings have been achieved by following the instructions set out above. Use of alternative ecomponents or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool products in applications are or published by Rockwool ULI. Expert advises should be sought where such applications are contempliated. The information contained in this drawing is believed to be correct at the descense of upblication, and is based upon tested and entities of the published of the published and entities of the correct at the descense of the specification of the published and entities of the published of the specification of the published drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this drawing may be affected by pertinent changes in the law or regulatory requirements and afterations or a mendments to the specification of Rockwool published.

![](_page_37_Figure_0.jpeg)

![](_page_38_Figure_0.jpeg)

![](_page_39_Picture_0.jpeg)

# FIRESTOPPING PROJECT DETAILS

• Linear Details (Top Of Blockwork and Vertical Gaps Blockwork to Steel)

	1	Firestopping Matrix - Linear Seals	
	0mm - 25mm	25mm - 50mm	51mm to 150mm
Non Fire Rated Plasterboard Partitions	* Install 15mm bead of Intumescent Acoustic Mastic	* Push fit rockwool insulation into the gap (tight fit) leaving 15mm to face of the wall then install a 15mm deep bead of Rockwool Acoustic Intumescent Sealant that finishes flush with face of the wall. This should be each side.	* Install Single 50mm Ablative batt centrally above the wall then Intumescent Acoustic Mastic to the edges. For optimum acoustics install double batt (one finishing flush with each side of a partition).
60min Fire Rated Plasterboard Partitions	<ul> <li>* Blockwork Wall to Concrete Soffit - 10mm - 25 installed to a gap size of 20mm - 50mm. The dept 50mm gap must have a 25mm deep bead of seals As detail RWSD-AIS-0001 (A)</li> <li>Achieves 120min Integrity &amp; 30-60min Insulation need to be installed form both sides if there is a</li> <li>* Blockwork Wall to Steel Beam - 10mm - 25mm installed to a gap size of 20mm - 50mm. The dept 50mm gap must have a 25mm deep bead of seals As detail RWSD-AIS-0001 (C)</li> <li>Gaps up to 20mm achieve 120min Integrity &amp; 30 Gaps 21mm - 50mm Achieves 45min Integrity &amp;</li> </ul>	mm deep bead of Rockwool Acoustic Intumescent Sealant can be th of the Mastic will always be 50% of the width being sealed i.e. a ant. RWA45 or PE Rod to be used as backing. <b>In (This rating is acheived by installing from 1 side only, would only twin block wall with cavity)</b> deep bead of Rockwool Acoustic Intumescent Sealant can be th of the Mastic will always be 50% of the width being sealed i.e. a ant. RWA45 or PE Rod to be used as backing. <b>Imin Insulation</b> <b>30min Insulation (This rating is acheived by installing from 1 side</b>	<ul> <li>* Blockwork Wall to Flat Concrete or Steel Soffit (Can achieve 2.6m high seal if installed in landscape or 1,200mm high seal if installed in portrait): Install 60mm Ablative batt centrally above the wall then Intumescent Acoustic Mastic to the edges. If up to steelwork it will also need an additional 150mm rip of batt eaither side which is to be mechanically fixed as shown. As per detail RWSD- ACB-1301 Achieves 60min Integrity &amp; 60min Insulation</li> </ul>
120min Fire Rated Walls	only, would recommend installing from both sid * Plasterboard Wall to Concrete Soffit at Head o Sealant to a maximum gap size of 20mm (Head th As detail RWSD-AIS-0001 (F) Achieves 120min Integrity & 120min Insulation * Plasterboard to Masonry (Vertical abutment) - maximum gap size of 20mm. RWA45 or PE Rod to As detail RWSD-AIS-0001 (E) Achieves 120min Integrity & 120min Insulation If another scenario such as above walls to profile	es in order to achieve 60min Integrity f Wall - 25mm deep bead of Rockwool Acoustic Intumescent rack acts as backing). 12.5mm deep bead of Rockwool Acoustic Intumescent Sealant to a be used as backing. ed deck then use the >50mm Details	<ul> <li>Where greater than 60min Required or where not to a flat soffit (or both):</li> <li>Option A: Supply and install AIM Firestop Blocks to fit profile of Metal Deck</li> <li>Achieves up to 120min Integrity &amp; Insulation</li> <li>Option B (If above blockwork) Compression fit</li> <li>Linear Firestop 2a ensuring it is compresses by at least 5%. As per detail RWSD-LTF-0001</li> <li>Achieves 120min - 240min Integrity &amp; Insulation</li> </ul>

![](_page_41_Figure_0.jpeg)

<sup>(</sup>V10/NOV22)

![](_page_42_Figure_0.jpeg)

# **AIM Fire Stop Blocks**

AIM High Density Rockwool stone wool Fire and Smoke Stop Blocks for apertures in buildings, especially the flutes of metal profiles

![](_page_43_Picture_2.jpeg)

![](_page_43_Picture_3.jpeg)

![](_page_43_Picture_4.jpeg)

AIM Fire Stop Blocks are made from high density Rockwool stone wool. Incorporated into the building during construction, they are used to seal apertures and are permanently held in place by compression. They can also be used within metal cladding as a fire break and to protect the top flange of steel beams.

## ROCKWOOL

#### Specification

Minimum block length: 50mm

- No mastics or sealants required
- Tested to BS 476 part 20 and assessed by Warrington Fire Research Centre
- Ozone depletion potential of zero, no CFCs or HCFCs used in manufacture
- Global warming potential = zero
- Applications
- Composite Flooring Profiles
- Dovetail Composite Flooring Profiles
- Metal Decking, Roofing and Cladding

#### **Fire Performance**

Fire Resistance	Minimum Length of Fire Stop Block mm				
Minutes	Height up to 75mm	Height 76mm -→300mm			
30	50	50			
60	60	75			
120	75	100			
240	100 EHD*	100 EHD*			

\*EHD = Extra high density barrier with lap joints EHD is not required for dovetail blocks

Length measures the amount of fire stop material required. The total length may be provided by two shorter blocks (i.e. two 50mm long blocks are suitable for a minimum length requirement of 100mm).

#### **Acoustic Rating**

When installed above a partition and where an imperforate 12.5mm plasterboard ceiling is installed to abut the partition below on both sides, the room-to-room sound reduction, on the path of the Fire Stop Block, will be at least 47dB – average sound reduction index.

#### Installation

AIM Fire Stop Blocks are push fitted into place; they must fit tightly and completely. Dovetail fire stops are supplied as rectangular blocks, which are pinch fitted into the profile, then pushed into place. Slip plates may be used for difficult installations.

#### Air leakage

AIM ablative coated fire stop blocks provide a robust solution to air leakage requirements. These are available to suit most major cladding and decking profiles. See page 19 (AIM Construction shapes).

#### Suggested accessory

AIM Intumescent mastic.

![](_page_44_Figure_0.jpeg)

The published fire ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd, does not accept responsibility for the consequences of using Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advec should be sought where such applications are contemplated. The information contained in this drawing is believed to be correct at the date of publication, and is based upon tested and certified solutions. The policy of Rockwool Ltd. Expert advec should be sought where such applications are contemplated. The information contained in this drawing is believed to be correct at the date of publication, and is based upon tested and certified solutions. The policy of Rockwool Ltd. Expert advec are working from the latest published drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this drawing may be affected by pertinent changes in the law or Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this drawing may be affected by pertinent changes in the law or Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this drawing may be affected by pertinent changes in the law or Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this drawing may be affected by pertinent changes in the law or Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this drawing may be affected by pertinent changes in the law or Rockwool will endeavour to keep its publications or another to the specification of Rockwool products.

Revision:

![](_page_45_Picture_0.jpeg)

# FIRESTOPPING PROJECT DETAILS

• Appendix

![](_page_46_Picture_0.jpeg)

CLIENT: SPARTA SYSTEMS

PROJECT: PATHOLOGY BUILDING

#### FIRE RATING REQUIRMENT:

**INTEGRITY:** 60 minutes

INSULATION:

N/A

#### **SUPPORTING DATA:**

WF 385718 – Double 50mm batt seal cables WF 411458 – Trunking penetrations WF 406434 – Large steel pipe WF 335645-4 – Double 50mm batt FOA

#### **ASSESSOR:**

Ruth Barnes (Trainee Assessor) Fire Technical Consultant

#### **REVIEWER:**

Lewis Ham (Senior Assessor) Fire Protection Technical Lead

#### CONTACT

ROCKWOOL LIMITED PENCOED, BRIDGEND, CF35 6NY 01656 862261

This detail has been prepared for where an application sits outside of ROCKWOOL test data and has been assessed as the most likely solution to achieve the detailed fire rating. If, however, a formal Fire Rating is required then this must be obtained via a formal test/assessment from a suitably accredited UKAS Fire Laboratory. The evaluation relates to the expected Fire Resistance performance, should the detail be subjected to a test in accordance with an appropriate EN fire resistance test standard (unless specified otherwise) against which this evaluation has been made. This evaluation is only suitable for the above referenced project and shall be submitted to the site design team for their approval of the detail's acceptability.

The published fire ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd. does not accept responsibility for the consequences of using Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advice should be sought where such applications are contemplated.

The information contained in this drawing is believed to be correct at the date of publication and is based upon tested and certified solutions. The policy of Rockwool Ltd. is one of constant improvement. Installers should therefore ensure that they are working from the latest published drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this detail may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of Rockwool products.

#### **TECHNICAL EVALUATION REQUEST**

ROCKWOOL have been formally approached to offer our opinion on the expected fire performance of a 100mm x 100mm SHS and a unistrut channel through a double 50mm ablative coated batt seal within a flexible wall construction.

The following technical evaluation has been produced following the guidance set out in the Passive Fire Protection Forum (PFPF) *Guide To* Undertaking Technical Assessments of Fire Performance of Construction Products Based on Fire Test Evidence (2021).

This technical evaluation has been prepared and checked by ROCKWOOL product assessors with the necessary competence who follow the principals outlined in the PFPF guidelines to undertaking assessments in lieu of direct fire test data.

ROCKWOOL have adopted the processes outlined in the PFPF guide to manage the conflict of interest inherent with a manufacturers technical evaluation compared to an assessment developed by UKAS accredited third party, allowing for a clear a rigorous examination of the proposal by the approving body.

#### JUSTIFICATION OF PROPOSAL

(All referenced fire resistance data has been tested in accordance with BS EN 1366-3 unless otherwise stated – this technical evaluation has been requested by FIRAS)

The following assumptions have been made in developing the technical evaluation:

- The flexible wall construction has a proven fire resistance rating which is at least equal to the required performance of the seal.
- The penetrations are non-combustible with a melting or decomposition point higher than the nominal furnace temperature at the intended classification.
- The size of the seals are no greater than those stated on the relevant ROCKWOOL standard details and classification documents.

The following report reviews the available fire resistance test data in support of double 50mm ablative coated batt aperture seals and face fix seals with a SHS & Unistrut penetration within a double skin flexible wall construction for 60 minutes integrity only.

#### FACE FIX BATT APPLICTIONS

Face fixing ablative coated batts to flexible wall constructions is directly supported for fire resistance periods up to 120 minutes as stated within ROCKWOOL 50mm field of application document (WF 335645-4). Face fix applications achieve higher periods of fire resistance when compared to aperture seal applications, this is because the seal is effectively increased in overall thickness due to the cavity between the two ablative batt layers.

![](_page_47_Picture_0.jpeg)

CLIENT: SPARTA SYSTEMS

PROJECT: PATHOLOGY BUILDING

#### FIRE RATING REQUIRMENT:

**INTEGRITY:** 60 minutes

INSULATION: N/A

#### **SUPPORTING DATA:**

WF 385718 – Double 50mm batt seal cables WF 411458 – Trunking penetrations WF 406434 – Large steel pipe WF 335645-4 – Double 50mm batt FOA

#### **ASSESSOR:**

Ruth Barnes (Trainee Assessor) Fire Technical Consultant

#### **REVIEWER:**

Lewis Ham (Senior Assessor) Fire Protection Technical Lead

#### CONTACT

ROCKWOOL LIMITED PENCOED, BRIDGEND, CF35 6NY 01656 862261

This detail has been prepared for where an application sits outside of ROCKWOOL test data and has been assessed as the most likely solution to achieve the detailed fire rating. If, however, a formal Fire Rating is required then this must be obtained via a formal test/assessment from a suitably accredited UKAS Fire Laboratory. The evaluation relates to the expected Fire Resistance performance, should the detail be subjected to a test in accordance with an appropriate EN fire resistance test standard (unless specified otherwise) against which this evaluation has been made. This evaluation is only suitable for the above referenced project and shall be submitted to the site design team for their approval of the detail's acceptability.

The published fire ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd. does not accept responsibility for the consequences of using Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advice should be sought where such applications are contemplated.

The information contained in this drawing is believed to be correct at the date of publication and is based upon tested and certified solutions. The policy of Rockwool Ltd. is one of constant improvement. Installers should therefore ensure that they are working from the latest published drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this detail may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of Rockwool products.

#### DOUBLE BATT APERTURE SEAL DATA

In line with EN 15882-3:2009 – Extended applications of results from fire resistance tests for service installations - Part 3: Penetration seals. Test data established from double ablative batt aperture seals is relevant for face fix applications as increasing the air gap between batt layers is permitted.

A.2.3 Boards

Variation	Rules
Change of board material	Not permitted
Increase in board thickness	Permitted (supporting evidence for framing systems/fixings must be provided)
Decrease in board thickness	Not permitted
Change in nominal board density	Not permitted
Change of coating material	Not permitted
Change in coating thickness	Not permitted
Change of perimeter / joint adhesive(s) / sealants or gap fillers	Not permitted
Change of air gap between boards	Permitted between the size of air gaps demonstrated by test
Change of internal support frames for boards	Not permitted

#### Extract from EN 15882-3

The following test references relate to double 50mm ablative batt aperture seals.

#### **UNISTRUT P1000 CHANNEL**

The P1000 channel has not been directly tested through a double ablative batt seal but it is our opinion that results from cable trays and cable ladders are relevant for this penetration type. The channel is non combustible with dimensions 41mm x 41mm x 2.5mm thick.

Cable ladders that form part of the standard configuration as defined by BS EN 1366-3 are typically 350mm x 125mm x 1.5mm, similarly cable trays are 500mm x 60mm x 1.5mm. The cable carriers are larger and thinner than the P1000 channel, making them more prone to deflection and movement under fire conditions. The cable carriers are also under load to replicate cable carrier full with cables. In our view these conditions make the standard configuration more onerous than a single P1000 channel.

Fire resistance test WF 385718 consisted of a double 50mm ablative batt seal which was penetrated by the standard cable configuration.

![](_page_48_Picture_0.jpeg)

CLIENT: SPARTA SYSTEMS

PROJECT: PATHOLOGY BUILDING

#### **FIRE RATING REQUIRMENT:**

INTEGRITY: 60 minutes

**INSULATION:** 

N/A

#### **SUPPORTING DATA:**

WF 385718 - Double 50mm batt seal cables WF 411458 - Trunking penetrations WF 406434 - Large steel pipe WF 335645-4 - Double 50mm batt FOA

#### **ASSESSOR:**

Ruth Barnes (Trainee Assessor) Fire Technical Consultant

#### **REVIEWER:**

Lewis Ham (Senior Assessor) Fire Protection Technical Lead

#### CONTACT

ROCKWOOL LIMITED PENCOED, BRIDGEND, CF35 6NY 01656 862261

This detail has been prepared for where an application sits outside of ROCKWOOL test data and has been assessed as the most likely solution to achieve the detailed fire rating. If, however, a formal Fire Rating is required then this must be obtained via a formal test/assessment from a suitably accredited UKAS Fire Laboratory. The evaluation relates to the expected Fire Resistance performance, should the detail be subjected to a test in accordance with an appropriate EN fire resistance test standard (unless specified otherwise) against which this evaluation has been made. This evaluation is only suitable for the above referenced project and shall be submitted to the site design team for their approval of the detail's acceptability.

The published fire ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd. does not accept responsibility for the consequences of using Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advice should be sought where such applications are contemplated.

The information contained in this drawing is believed to be correct at the date of publication and is based upon tested and certified solutions. The policy of Rockwool Ltd. is one of constant improvement. Installers should therefore ensure that they are working from the latest published drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this detail may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of Rockwool products.

		No. 385718 Page 20 of 76
Item		Description
Cable penetration services Position 2.1	:	350 mm wide by 125 mm deep by 1.5 mm thick steel cable ladder supporting one D1, one D2 (each 4 x 185 $\eta$ ) and two E (1 x 185 mm) cables. The cable penetrations and ladder are litted through the wall before the barrier is assembled
Position 2.2	:	250 mm wide by 125 mm deep by 1.5 mm thick steel cable ladder supporting one D3 (4 x 185 mm <sup>2</sup> ) cable. The cable penetration and ladder is fitted through the wall before the barrier is assembled
Position 2.3	:	450 mm wide by 25 mm high by 1.0 mm thick perforated steel cable tray supporting ten A1, ten A2 and ten A3 (each 5 x1, 5 mm?), wo B (1 x5 5 mm?), one C1, one C2 and one C3 (each 4 x 95 mm?) cables. The cable penetrations and tray are fitted through the wall before the barrier is assembled
Position 2.4	:	500 mm wide by 60 mm high by 1.5 mm thick upperfortated sele cable tay supporting a 100 mm <sup>2</sup> diameter bundle of F (20 x 2 x 0.6 mm <sup>3</sup> ) telecom cables, one G (1 ( x 95 mm <sup>3</sup> ), one G (1 ( x 185 mm <sup>2</sup> ) cables, three rigid I PVC conduits (16 mm diameter by 1.0 mm wall thickness), all to the requirements of A.110 of EN 1366-3. The cable penetrations and tray are fitted through the wall before the barrier is asembled
Loading of cable trays Position 2.1 Position 2.2 Position 2.3 Position 2.4		9kg 6kg 15kg 15kg

#### WF 385718 - Cable carrier specification

![](_page_48_Figure_21.jpeg)

#### WF 385718 - Opening 2 standard cable config. Through double 50mm ablative coated batt

![](_page_49_Picture_0.jpeg)

CLIENT: SPARTA SYSTEMS

PROJECT: PATHOLOGY BUILDING

#### FIRE RATING REQUIRMENT:

**INTEGRITY:** 60 minutes

INSULATION:

N/A

#### **SUPPORTING DATA:**

WF 385718 – Double 50mm batt seal cables WF 411458 – Trunking penetrations WF 406434 – Large steel pipe WF 335645-4 – Double 50mm batt FOA

#### **ASSESSOR:**

Ruth Barnes (Trainee Assessor) Fire Technical Consultant

#### **REVIEWER:**

Lewis Ham (Senior Assessor) Fire Protection Technical Lead

#### CONTACT

ROCKWOOL LIMITED PENCOED, BRIDGEND, CF35 6NY 01656 862261

This detail has been prepared for where an application sits outside of ROCKWOOL test data and has been assessed as the most likely solution to achieve the detailed fire rating. If, however, a formal Fire Rating is required then this must be obtained via a formal test/assessment from a suitably accredited UKAS Fire Laboratory. The evaluation relates to the expected Fire Resistance performance, should the detail be subjected to a test in accordance with an appropriate EN fire resistance test standard (unless specified otherwise) against which this evaluation has been made. This evaluation is only suitable for the above referenced project and shall be submitted to the site design team for their approval of the detail's acceptability.

The published fire ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd. does not accept responsibility for the consequences of using Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advice should be sought where such applications are contemplated.

The information contained in this drawing is believed to be correct at the date of publication and is based upon tested and certified solutions. The policy of Rockwool Ltd. is one of constant improvement. Installers should therefore ensure that they are working from the latest published drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this detail may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of Rockwool products.

Specimen 2	li	Insulation		
(Service)	Cotton	Sustained	Gap	(minutes)
	pad	flaming	gauge	
350 mm ladder	132*	132*	132*	97
D1	132*	132*	132*	81
E (2No.)	132*	132*	132*	77
D2	132*	132*	132*	120
Position 2.1				
Overall	132*	132*	132*	81
250 mm ladder	132*	132*	132*	132*
D3	132*	132*	132*	73
Position 2.2				
Overall	132*	132*	132*	73
450 mm				
perforated tray	126	126	132*	80
A1 (10 No.)	132*	132*	132*	128
A2 (10 No.)	132*	132*	132*	80
A3 (10 No.)	132*	132*	132*	114
B (2 No.)	126	126	132*	58
C1	126	126	132*	65
C3	126	126	132*	69
C2	126	126	132*	74
Position 2.3				
Overall	126	126	132*	58

#### WF 385718 - Test results

The cable carriers within this test consistently achieved a fire resistance rating of over 120 minutes integrity which is a 100% increase in required performance for this scheme which is 60 minutes integrity only. This significant overrun in performance gives us confidence in the unistrut channel achieving at least 60 minutes integrity when penetrating a double 50mm ablative batt seal.

#### 100MM X 100MM x 3.6MM SQUARE HOLLOW SECTION (SHS)

SHS are not defined within BS EN 1366-3 and at this time ROCKWOOL have no supporting direct test data. With this in mind we make reference to our trunking testing. As detailed in RWSD-ACB-0103 (WF 411458) a 100mm x 100mm x 1.2mm trunking achieves a fire resistance rating of 60 minutes integrity when sealed by a double 50mm ablative batt seal in a flexible wall. Trunking / containment is thinner gauge than a SHS which make them more prone to deflection under fire conditions. The more onerous trunking archives a fire resistant rating equal to that required for this scheme at 60 minutes integrity.

![](_page_49_Figure_24.jpeg)

WF 411458 - Specimen 3 K&L 100x100x1.2mm trunking

![](_page_50_Picture_0.jpeg)

CLIENT: SPARTA SYSTEMS

PROJECT: PATHOLOGY BUILDING

#### FIRE RATING REQUIRMENT:

**INTEGRITY:** 60 minutes

INSULATION:

N/A

#### **SUPPORTING DATA:**

WF 385718 – Double 50mm batt seal cables WF 411458 – Trunking penetrations WF 406434 – Large steel pipe WF 335645-4 – Double 50mm batt FOA

#### **ASSESSOR:**

Ruth Barnes (Trainee Assessor) Fire Technical Consultant

#### **REVIEWER:**

Lewis Ham (Senior Assessor) Fire Protection Technical Lead

#### CONTACT

ROCKWOOL LIMITED PENCOED, BRIDGEND, CF35 6NY 01656 862261

This detail has been prepared for where an application sits outside of ROCKWOOL test data and has been assessed as the most likely solution to achieve the detailed fire rating. If, however, a formal Fire Rating is required then this must be obtained via a formal test/assessment from a suitably accredited UKAS Fire Laboratory. The evaluation relates to the expected Fire Resistance performance, should the detail be subjected to a test in accordance with an appropriate EN fire resistance test standard (unless specified otherwise) against which this evaluation has been made. This evaluation is only suitable for the above referenced project and shall be submitted to the site design team for their approval of the detail's acceptability.

The published fire ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd. does not accept responsibility for the consequences of using Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advice should be sought where such applications are contemplated.

The information contained in this drawing is believed to be correct at the date of publication and is based upon tested and certified solutions. The policy of Rockwool Ltd. is one of constant improvement. Installers should therefore ensure that they are working from the latest published drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this detail may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of Rockwool products.

3 / H	60*	60*	60*	60*
3 / 1	60*	60*	60*	60*
3 / J	60*	60*	60*	60*
3 / K	60*	60*	60*	60*
3/ L	60*	60*	60*	60*
3 / Seal	60*	60*	60*	60*
3 / Overall	60*	60*	60*	60*

WF 411458 - Specimen 3 K&L 60 minutes integrity

We also make reference to WF 406434 (Draft). In this test an unlagged 610mm x 5mm steel pipe passes through a double 50mm ablative batt seal within a masonry construction. Specimen A1 achieved a fire resistance rating of 220 minutes integrity and 20 minutes insulation.

The 220 minutes integrity rating achieved is a significant overrun in performance and although this test consisted of a double 50mm ablative batt seal sealed from both sides the result gives us confidence in the ability of double 50mm ablative batt seals in providing an effective seal for resistance periods above 120 minutes integrity for large non-combustible objects.

![](_page_50_Picture_23.jpeg)

WF 406434 - Elevation

![](_page_50_Picture_25.jpeg)

WF 406434 - Unexposed Face after test duration of 120 minutes

		Int			
Specimen	Penetration	Cotton Pad	Sustained flaming	Gap Gauge	Insulation (minutes)
	A1	229	244*	244*	20
Α	A2	244*	244*	244*	14
	Overall	229	244*	244*	14
	B1(Cluster)	199	199	244*	71

WF 406434 - Results table - A1 220 integrity 20 minutes insulation

![](_page_51_Picture_0.jpeg)

CLIENT: SPARTA SYSTEMS

PROJECT: PATHOLOGY BUILDING

#### FIRE RATING REQUIRMENT:

**INTEGRITY:** 60 minutes

INSULATION: N/A

#### **SUPPORTING DATA:**

WF 385718 – Double 50mm batt seal cables WF 411458 – Trunking penetrations WF 406434 – Large steel pipe WF 335645-4 – Double 50mm batt FOA

#### **ASSESSOR:**

Ruth Barnes (Trainee Assessor) Fire Technical Consultant

#### **REVIEWER:**

Lewis Ham (Senior Assessor) Fire Protection Technical Lead

#### CONTACT

ROCKWOOL LIMITED PENCOED, BRIDGEND, CF35 6NY 01656 862261

This detail has been prepared for where an application sits outside of ROCKWOOL test data and has been assessed as the most likely solution to achieve the detailed fire rating. If, however, a formal Fire Rating is required then this must be obtained via a formal test/assessment from a suitably accredited UKAS Fire Laboratory. The evaluation relates to the expected Fire Resistance performance, should the detail be subjected to a test in accordance with an appropriate EN fire resistance test standard (unless specified otherwise) against which this evaluation has been made. This evaluation is only suitable for the above referenced project and shall be submitted to the site design team for their approval of the detail's acceptability.

The published fire ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd. does not accept responsibility for the consequences of using Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advice should be sought where such applications are contemplated.

The information contained in this drawing is believed to be correct at the date of publication and is based upon tested and certified solutions. The policy of Rockwool Ltd. is one of constant improvement. Installers should therefore ensure that they are working from the latest published drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this detail may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of Rockwool products. Based on the above, and in lieu of direct supporting test data for a P1000 channel and 100x100mm SHS. It is our opinion that if these services penetrated a double 50mm ablative batt seal and were tested in accordance with BS EN 1366-3 a fire resistance rating of 60 minutes integrity would be achieved.

#### SIGNATORIES

Assessor: Ruth Barnes (Trainee Assessor) Fire Technical Consultant

Reviewer: Lewis Ham (Senior Assessor) Fire Protection Technical Lead

![](_page_52_Picture_0.jpeg)

CLIENT: SPARTA SYSTEMS

PROJECT: PATHOLOGY BUILDING

#### FIRE RATING REQUIRMENT:

**INTEGRITY:** 60 minutes

**INSULATION:** 60 minutes

#### **SUPPORTING DATA:**

WF 411454 – Double 50mm batt Flex Conduit WF 335645-4 – Batt 50mm FOA UL-EU-01208-CPR – Batt UL

#### **ASSESSOR:**

Ruth Barnes (Trainee Assessor) Fire Technical Consultant

#### **REVIEWER:**

Lewis Ham (Senior Assessor) Fire Protection Technical Lead

#### CONTACT

ROCKWOOL LIMITED PENCOED, BRIDGEND, CF35 6NY 01656 862261

This detail has been prepared for where an application sits outside of ROCKWOOL test data and has been assessed as the most likely solution to achieve the detailed fire rating. If, however, a formal Fire Rating is required then this must be obtained via a formal test/assessment from a suitably accredited UKAS Fire Laboratory. The evaluation relates to the expected Fire Resistance performance, should the detail be subjected to a test in accordance with an appropriate EN fire resistance test standard (unless specified otherwise) against which this evaluation has been made. This evaluation is only suitable for the above referenced project and shall be submitted to the site design team for their approval of the detail's acceptability.

The published fire ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd. does not accept responsibility for the consequences of using Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advice should be sought where such applications are contemplated.

The information contained in this drawing is believed to be correct at the date of publication and is based upon tested and certified solutions. The policy of Rockwool Ltd. is one of constant improvement. Installers should therefore ensure that they are working from the latest published drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this detail may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of Rockwool products.

#### **TECHNICAL EVALUATION REQUEST**

ROCKWOOL have been formally approached to offer our opinion on the expected fire performance of a face fixed 50mm thick ablative coated batt seal fixed to a flexible wall construction with 25mm diameter continuous rigid non-combustible conduit penetrations.

The following technical evaluation has been produced following the guidance set out in the Passive Fire Protection Forum (PFPF) *Guide To* Undertaking Technical Assessments of Fire Performance of Construction Products Based on Fire Test Evidence (2021).

This technical evaluation has been prepared and checked by ROCKWOOL product assessors with the necessary competence who follow the principals outlined in the PFPF guidelines to undertaking assessments in lieu of direct fire test data.

ROCKWOOL have adopted the processes outlined in the PFPF guide to manage the conflict of interest inherent with a manufacturers technical evaluation compared to an assessment developed by UKAS accredited third party, allowing for a clear a rigorous examination of the proposal by the approving body.

#### JUSTIFICATION OF PROPOSAL

(All referenced fire resistance data has been tested in accordance with BS EN 1366-3 unless otherwise stated)

The following assumptions have been made in developing the technical evaluation:

- The flexible wall construction has a proven fire resistance rating which is at least equal to the required performance of the seal.
- The conduits are continuous i.e., not flush or projecting open ended conduits
- The seal size is equal to or less then 900mm (h) x 600mm (w)

#### FACE FIX BATT APPLICTIONS

Face fixing ablative coated batts to flexible wall constructions is directly supported for fire resistance periods up to 120 minutes as stated within ROCKWOOL 50mm field of application document (WF 335645-4). Face fix applications achieve higher periods of fire resistance when compared to aperture seal applications, this is because the seal is effectively increased in overall thickness due to the cavity between the two ablative batt layers.

#### DOUBLE BATT APERTURE SEAL DATA

In line with EN 15882-3:2009 – Extended applications of results from fire resistance tests for service installations - Part 3: Penetration seals. Test data established from double ablative batt aperture seals is relevant for face fix applications as increasing the air gap between batt layers is permitted.

![](_page_53_Picture_0.jpeg)

CLIENT: SPARTA SYSTEMS

PROJECT: PATHOLOGY BUILDING

#### FIRE RATING REQUIRMENT:

**INTEGRITY:** 60 minutes

**INSULATION:** 60 minutes

#### **SUPPORTING DATA:**

WF 411454 – Double 50mm batt Flex Conduit WF 335645-4 – Batt 50mm FOA UL-EU-01208-CPR – Batt UL

#### **ASSESSOR:**

Ruth Barnes (Trainee Assessor) Fire Technical Consultant

#### **REVIEWER:**

Lewis Ham (Senior Assessor) Fire Protection Technical Lead

#### CONTACT

ROCKWOOL LIMITED PENCOED, BRIDGEND, CF35 6NY 01656 862261

This detail has been prepared for where an application sits outside of ROCKWOOL test data and has been assessed as the most likely solution to achieve the detailed fire rating, If, however, a formal Fire Rating is required then this must be obtained via a formal test/assessment from a suitably accredited UKAS Fire Laboratory. The evaluation relates to the expected Fire Resistance performance, should the detail be subjected to a test in accordance with an appropriate EN fire resistance test standard (unless specified otherwise) against which this evaluation has been made. This evaluation is only suitable for the above referenced project and shall be subject to the site design team for their approval of the detail's acceptability.

The published fire ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd. does not accept responsibility for the consequences of using Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advice should be sought where such applications are contemplated.

The information contained in this drawing is believed to be correct at the date of publication and is based upon tested and certified solutions. The policy of Rockwool Ltd. is one of constant improvement. Installers should therefore ensure that they are working from the latest published drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this detail may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of Rockwool products. A.2.3 Boards

Variation	Rules
Change of board material	Not permitted
Increase in board thickness	Permitted (supporting evidence for framing systems/fixings must be provided)
Decrease in board thickness	Not permitted
Change in nominal board density	Not permitted
Change of coating material	Not permitted
Change in coating thickness	Not permitted
Change of perimeter / joint adhesive(s) / sealants or gap fillers	Not permitted
Change of air gap between boards	Permitted between the size of air gaps demonstrated by test
Change of internal support frames for boards	Not permitted

#### Extract from EN 15882-3

#### CONDUITS

Specimen I of WF 411454 consisted of 3 No. 25mm diameter flexible steel conduits with ablative liquid coatback (left) and 3 No. 25mm diameter flexible steel conduits without coatback (right). The three conduits were positioned in a linear formation on a perforated cable tray through a double 50mm ablative coated batt seal in a 100mm thick flexible wall construction.

![](_page_53_Figure_23.jpeg)

WF 411454 - Specimen 4(I) - Flexible steel conduits

![](_page_54_Picture_0.jpeg)

CLIENT: SPARTA SYSTEMS

PROJECT: PATHOLOGY BUILDING

#### FIRE RATING REQUIRMENT:

**INTEGRITY:** 60 minutes

**INSULATION:** 60 minutes

#### **SUPPORTING DATA:**

WF 411454 – Double 50mm batt Flex Conduit WF 335645-4 – Batt 50mm FOA UL-EU-01208-CPR – Batt UL

#### **ASSESSOR:**

Ruth Barnes (Trainee Assessor) Fire Technical Consultant

#### **REVIEWER:**

Lewis Ham (Senior Assessor) Fire Protection Technical Lead

#### CONTACT

ROCKWOOL LIMITED PENCOED, BRIDGEND, CF35 6NY 01656 862261

This detail has been prepared for where an application sits outside of ROCKWOOL test data and has been assessed as the most likely solution to achieve the detailed fire rating. If, however, a formal Fire Rating is required then this must be obtained via a formal test/assessment from a suitably accredited UKAS Fire Laboratory. The evaluation relates to the expected Fire Resistance performance, should the detail be subjected to a test in accordance with an appropriate EN fire resistance test standard (unless specified otherwise) against which this evaluation has been made. This evaluation is only suitable for the above referenced project and shall be submitted to the site design team for their approval of the detail's acceptability.

The published fire ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd. does not accept responsibility for the consequences of using Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advice should be sought where such applications are contemplated. The information contained in this drawing is believed to be correct

The information contained in this drawing is believed to be correct at the date of publication and is based upon tested and certified solutions. The policy of Rockwool Ltd, is one of constant improvement. Installers should therefore ensure that they are working from the latest published drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this detail may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of Rockwool products.

Individual temperatures recorded on the unexposed surface of Specimen 4 Service I

Time	T/C						
	Number						
Mins	45	46	47	48	49	50	51
	Deg. C						
0	21	20	21	20	21	15	16
4	23	34	23	32	22	18	17
8	32	46	28	43	25	22	18
12	56	39	47	38	37	25	24
16	65	37	54	37	51	28	35
20	69	36	61	38	65	32	48
24	74	36	70	38	76	35	60
28	77	37	74	39	80	38	70
32	83	38	80	41	82	41	74
36	85	40	82	43	83	44	73
40	86	41	83	45	83	47	73
44	89	43	83	47	83	49	73
48	92	45	82	49	83	52	74
52	97	47	84	52	83	55	74
56	100	49	84	55	85	58	76
60	105	50	85	56	86	60	77
64	111	51	87	56	88	62	77
68	115	52	88	56	88	64	76
72	120	53	91	57	90	65	75
76	125	53	95	58	93	67	76
80	131	54	99	59	98	68	79
84	135	55	103	59	102	69	81
88	140	56	109	61	107	70	85
92	144	57	115	62	113	72	91
96	148	58	122	63	120	72	97
100	153	59	128	64	125	74	104
104	158	59	135	65	132	74	109
108	160	61	139	67	136	77	116
112	163	62	142	68	139	79	124
116	165	63	145	70	142	81	130
120	168	65	150	72	147	82	139
124	172	68	153	74	150	84	143
128	179	69	161	77	158	88	153
132	182	73	166	83	164	97	157

#### WF 411454 – TC 45-50 – flexible conduits with coatback 120 minutes integrity & insulation

Time	T/C						
	Number						
Mins	52	53	54	55	56	57	58
	Deg. C						
0	16	17	18	18	18	14	14
4	18	20	78	21	28	21	58
8	23	36	86	41	58	46	100
12	35	47	75	57	94	60	78
16	43	55	76	64	94	66	77
20	51	66	82	72	95	70	80
24	54	71	89	75	123	74	88
28	60	74	95	77	139	78	95
32	66	75	104	80	150	84	104
36	71	76	113	84	159	91	113
40	78	76	120	88	164	95	120
44	82	78	128	94	170	101	129
48	87	79	135	96	176	108	135
52	91	82	143	98	185	115	144
56	94	84	149	102	190	122	150
60	97	88	154	108	196	129	156
62	98	89	156	111	198	132	158
63	99	89	157	112	200	133	159
64	99	90	158	113	201	134	161
68	102	92	162	118	206	139	165
72	103	96	167	124	211	145	171
76	106	99	172	129	216	150	177
80	109	105	179	136	222	156	184
84	112	110	181	140	223	159	187
88	115	116	186	146	228	164	192
92	118	122	191	152	234	170	196
96	121	127	195	157	238	175	201
100	124	132	199	163	241	181	205
104	125	141	205	170	247	187	210
108	139	144	212	175	253	196	215
112	133	152	220	183	261	202	222
116	137	159	227	191	268	209	228
120	144	171	240	213	280	223	238
124	143	180	247	226	287	233	245
128	155	191	258	239	298	243	257
132	157	197	268	250	306	253	277

#### WF 411454 – TC 53-58 – flexible conduits without coatback \*\*TC 56 – failure at 61 minutes\*\*

	Uveran	104	104	104	114
	F	132*	132*	132*	132*
	G	132*	132*	132*	132*
	н	132*	132*	132*	132*
4	- I	132*	132*	132*	61
	J	132*	132*	132*	113
	K	105	105	132*	107
	Overall	105	105	132*	61

WF 411454 – Specimen 4 (I) 132 minutes integrity 61 minutes insulation.

![](_page_55_Picture_0.jpeg)

CLIENT: SPARTA SYSTEMS

PROJECT: PATHOLOGY BUILDING

#### FIRE RATING REQUIRMENT:

**INTEGRITY:** 60 minutes

**INSULATION:** 60 minutes

#### **SUPPORTING DATA:**

WF 411454 – Double 50mm batt Flex Conduit WF 335645-4 – Batt 50mm FOA UL-EU-01208-CPR – Batt UL

#### **ASSESSOR:**

Ruth Barnes (Trainee Assessor) Fire Technical Consultant

#### **REVIEWER:**

Lewis Ham (Senior Assessor) Fire Protection Technical Lead

#### CONTACT

ROCKWOOL LIMITED PENCOED, BRIDGEND, CF35 6NY 01656 862261

This detail has been prepared for where an application sits outside of ROCKWOOL test data and has been assessed as the most likely solution to achieve the detailed fire rating. If, however, a formal Fire Rating is required then this must be obtained via a formal test/assessment from a suitably accredited UKAS Fire Laboratory. The evaluation relates to the expected Fire Resistance performance, should the detail be subjected to a test in accordance with an appropriate EN fire resistance test standard (unless specified otherwise) against which this evaluation has been made. This evaluation is only suitable for the above referenced project and shall be submitted to the site design team for their approval of the detail's acceptability.

The published fire ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd. does not accept responsibility for the consequences of using Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advice should be sought where such applications are contemplated.

The information contained in this drawing is believed to be correct at the date of publication and is based upon tested and certified solutions. The policy of Rockwool Ltd. is one of constant improvement. Installers should therefore ensure that they are working from the latest published drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this detail may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of Rockwool products. The above results confirm that flexible steel conduits on a cable tray through a double 50mm ablative batt seal can achieve a fire resistance rating of 120 minutes integrity and 60 minutes insulation with no additional treatment to the conduits (TCs 53 – 58). Similarly, a result of 120 minutes integrity and insulation is achieved with an additional L/I (Locally interrupted) coat back of ablative liquid is applied on the conduit.

In further support we refer to our single skin face fix batt coverage within UL-EU-01208-CPR. Where 20mm diameter flexible conduits achive a fire resiatnce rating of EI90 through a single skin flexible wall construction. Despite the slight increase in conduit size and rigidity on this scheme from we can see below that this application can achieve fire resistance ratings of up to 90 minutes.

![](_page_55_Figure_20.jpeg)

UL-EU-01208-CPR – Face Fix Ablative Batt

In summary, it is our opinion that if the seal detailed in this report were to undergo fire resistance testing in accordance with BS EN 1366-3:2021 a fire resistance rating of at least 60 minutes integrity and insulation would be achieved.

#### SIGNATORIES

Assessor: Ruth Barnes (Trainee Assessor) Fire Technical Consultant

27-CP-F0855 Issue: 3.1

Reviewer: Lewis Ham (Senior Assessor) Fire Protection Technical Lead

![](_page_56_Picture_0.jpeg)

CLIENT: SPARTA SYSTEMS

PROJECT: PATHOLOGY BUILDING

#### FIRE RATING REQUIRMENT:

**INTEGRITY:** 60 minutes

**INSULATION:** 60 minutes

#### **SUPPORTING DATA:**

WF 411454 – Double 50mm batt Flex Conduit WF 335645-4 – Batt 50mm FOA UL-EU-01208-CPR – Batt UL

#### **ASSESSOR:**

Ruth Barnes (Trainee Assessor) Fire Technical Consultant

#### **REVIEWER:**

Lewis Ham (Senior Assessor) Fire Protection Technical Lead

#### CONTACT

ROCKWOOL LIMITED PENCOED, BRIDGEND, CF35 6NY 01656 862261

This detail has been prepared for where an application sits outside of ROCKWOOL test data and has been assessed as the most likely solution to achieve the detailed fire rating. If, however, a formal Fire Rating is required then this must be obtained via a formal test/assessment from a suitably accredited UKAS Fire Laboratory. The evaluation relates to the expected Fire Resistance performance, should the detail be subjected to a test in accordance with an appropriate EN fire resistance test standard (unless specified otherwise) against which this evaluation has been made. This evaluation is only suitable for the above referenced project and shall be submitted to the site design team for their approval of the detail's acceptability.

The published fire ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd. does not accept responsibility for the consequences of using Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advice should be sought where such applications are contemplated. The information contained in this drawing is believed to be correct

The information contained in this drawing is believed to be correct at the date of publication and is based upon tested and certified solutions. The policy of Rockwool Ltd. is one of constant improvement. Installers should therefore ensure that they are working from the latest published drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this detail may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of Rockwool products.

![](_page_57_Picture_0.jpeg)

CLIENT: SPARTA SYSTEMS

PROJECT: PATHOLOGY BUILDING

#### FIRE RATING REQUIRMENT:

**INTEGRITY:** 60 minutes

INSULATION:

N/A

#### **SUPPORTING DATA:**

WF 411460 – Single skin conduits/sleeves UL-EU-01203-CPR – AIS UL RWSD-AIS-0101 – RW Standard Detail

#### **ASSESSOR:**

Ruth Barnes (Trainee Assessor) Fire Technical Consultant

#### **REVIEWER:**

Lewis Ham (Senior Assessor) Fire Protection Technical Lead

#### CONTACT

ROCKWOOL LIMITED PENCOED, BRIDGEND, CF35 6NY 01656 862261

This detail has been prepared for where an application sits outside of ROCKWOOL test data and has been assessed as the most likely solution to achieve the detailed fire rating. If, however, a formal Fire Rating is required then this must be obtained via a formal test/assessment from a suitably accredited UKAS Fire Laboratory. The evaluation relates to the expected Fire Resistance performance, should the detail be subjected to a test in accordance with an appropriate EN fire resistance test standard (unless specified otherwise) against which this evaluation has been made. This evaluation is only suitable for the above referenced project and shall be submitted to the site design team for their approval of the detail's acceptability.

The published fire ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd. does not accept responsibility for the consequences of using Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advice should be sought where such applications are contemplated.

The information contained in this drawing is believed to be correct at the date of publication and is based upon tested and certified solutions. The policy of Rockwool Ltd. is one of constant improvement. Installers should therefore ensure that they are working from the latest published drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this detail may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of Rockwool products.

#### **TECHNICAL EVALUATION REQUEST**

ROCKWOOL have been formally approached to offer our opinion on the expected fire performance of sealing the annular gap around a 25mm diameter continuous rigid steel conduit with an acoustic intumescent sealant annular gap seal.

The following technical evaluation has been produced following the guidance set out in the Passive Fire Protection Forum (PFPF) *Guide To* Undertaking Technical Assessments of Fire Performance of Construction Products Based on Fire Test Evidence (2021).

This technical evaluation has been prepared and checked by ROCKWOOL product assessors with the necessary competence who follow the principals outlined in the PFPF guidelines to undertaking assessments in lieu of direct fire test data.

ROCKWOOL have adopted the processes outlined in the PFPF guide to manage the conflict of interest inherent with a manufacturers technical evaluation compared to an assessment developed by UKAS accredited third party, allowing for a clear a rigorous examination of the proposal by the approving body.

#### JUSTIFICATION OF PROPOSAL

(All referenced fire resistance data has been tested in accordance with BS EN 1366-3 unless otherwise stated)

The following assumptions have been made in developing the technical evaluation:

- The flexible wall construction has a proven fire resistance rating which is at least equal to the required performance of the seal.
- The conduits are continuous i.e., not flush or projecting open ended conduits
- The annular gap seal is no greater than 10mm with a minimum depth of 12.5mm

The following report reviews the available fire resistance test data in support of an acoustic intumescent annular gap seal around a 25mm diameter continuous rigid conduit through a double skin flexible wall construction for 60 minutes integrity only.

#### **PROJECTING CONDUITS**

Projecting conduits are deemed a more onerous condition than rigid continuous conduits due to the additional seal requirements that are required between the conduit and the wall as well as the exposed ends of the conduit at each end.

Fire resistance test WF 411460 (BS EN 1366-3 2009) consisted of 42mm & 76mm diameter projecting copper conduits through a 75mm thick single skin flexible wall construction (Specimen H 42mm & Specimen G 76mm). The conduit was sealed with acoustic intumescent sealant between the sleeve and the plasterboard lining. The exposed ends of the conduit were

![](_page_58_Picture_0.jpeg)

CLIENT: SPARTA SYSTEMS

PROJECT: PATHOLOGY BUILDING

#### FIRE RATING REQUIRMENT:

**INTEGRITY:** 60 minutes

INSULATION:

N/A

#### **SUPPORTING DATA:**

WF 411460 – Single skin conduits/sleeves UL-EU-01203-CPR – AIS UL RWSD-AIS-0101 – RW Standard Detail

#### **ASSESSOR:**

Ruth Barnes (Trainee Assessor) Fire Technical Consultant

#### **REVIEWER:**

Lewis Ham (Senior Assessor) Fire Protection Technical Lead

#### CONTACT

ROCKWOOL LIMITED PENCOED, BRIDGEND, CF35 6NY 01656 862261

This detail has been prepared for where an application sits outside of ROCKWOOL test data and has been assessed as the most likely solution to achieve the detailed fire rating, if, however, a formal Fire Rating is required then this must be obtained via a formal test/assessment from a suitably accredited UKAS Fire Laboratory. The evaluation relates to the expected Fire Resistance performance, should the detail be subjected to a test in accordance with an appropriate EN fire resistance test standard (unless specified otherwise) against which this evaluation has been made. This evaluation is only suitable for the above referenced project and shall be submitted to the site design team for their approval of the detail's acceptability.

The published fire ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd. does not accept responsibility for the consequences of using Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advice should be sought where such applications are contemplated.

The information contained in this drawing is believed to be correct at the date of publication and is based upon tested and certified solutions. The policy of Rockwool Ltd. is one of constant improvement. Installers should therefore ensure that they are working from the latest published drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this detail may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of Rockwool products. also sealed with 45kg/m3 stonewool packing and 13mm depth of acoustic intumescent sealant.

![](_page_58_Figure_20.jpeg)

Do not scale. All dimensions are in mm

#### Extract from WF 411460 – Specimen Section

0	Int			
/ Service	Cotton Pad	Sustained flaming	Gap Gauge	(minutes)
Α	60*	60*	60*	60*
В	60*	60*	60*	60*
С	60*	60*	60*	60*
D	29	29	30"	29
E	60*	60*	60*	60*
F	60*	60*	60*	60*
G	60*	60*	60*	59
н	60*	60*	60*	60*

Extract from WF 411460 - Results Table

Specimen H & Specimen G achieved an integrity rating of 60 minutes which is equal to the required rating for this scheme. This test proves the interface between acoustic intumescent sealant, a non-combustible conduit and flexible wall can meet the required performance rating.

#### CONTINUOUS RIGID CONDUITS

In terms of supporting evidence for continuous rigid conduits we refer to non-combustible pipe penetrations through flexible wall constructions. Classification document UL-EU-01203-CPR provides direct coverage for copper and steel pipes up to 54mm diameter with a 1.2mm wall thickness through 75mm thick single skin flexible wall construction with a fire resistance rating of E 90. The 10mm annular gap is sealed with acoustic intumescent sealant to a depth of 12.5mm which is a direct reflection of the site condition for this scheme.

![](_page_59_Picture_0.jpeg)

CLIENT: SPARTA SYSTEMS

PROJECT: PATHOLOGY BUILDING

#### FIRE RATING REQUIRMENT:

**INTEGRITY:** 60 minutes

INSULATION:

N/A

#### **SUPPORTING DATA:**

WF 411460 – Single skin conduits/sleeves UL-EU-01203-CPR – AIS UL RWSD-AIS-0101 – RW Standard Detail

#### **ASSESSOR:**

Ruth Barnes (Trainee Assessor) Fire Technical Consultant

#### **REVIEWER:**

Lewis Ham (Senior Assessor) Fire Protection Technical Lead

#### CONTACT

ROCKWOOL LIMITED PENCOED, BRIDGEND, CF35 6NY 01656 862261

This detail has been prepared for where an application sits outside of ROCKWOOL test data and has been assessed as the most likely solution to achieve the detailed fire rating, If, however, a formal Fire Rating is required then this must be obtained via a formal test/assessment from a suitably accredited UKAS Fire Laboratory. The evaluation relates to the expected Fire Resistance performance, should the detail be subjected to a test in accordance with an appropriate EN fire resistance test standard (unless specified otherwise) against which this evaluation has been made. This evaluation is only suitable for the above referenced project and shall be submitted to the site design team for their approval of the detail's acceptability.

The published fire ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd. does not accept responsibility for the consequences of using Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advice should be sought where such applications are contemplated. The information contained in this drawing is believed to be correct

The information contained in this drawing is believed to be correct at the date of publication and is based upon tested and certified solutions. The policy of Rockwool Ltd. is one of constant improvement. Installers should therefore ensure that they are working from the latest published drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this detail may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of Rockwool products.

![](_page_59_Figure_19.jpeg)

UL-EU-01203-CPR - Non combustible

In lieu of direct fire resistance test data, it is our opinion that 25mm diameter continuous rigid steel conduits with an acoustic intumescent annular gap seal through a double skin flexible wall construction were to undergo fire resistance testing in accordance with BS EN 1366-3:2021 a fire resistance rating of at least 60 minutes integrity would be achieved.

#### SIGNATORIES

Assessor: Ruth Barnes (Trainee Assessor) Fire Technical Consultant

Reviewer: Lewis Ham (Senior Assessor) Fire Protection Technical Lead

![](_page_60_Figure_0.jpeg)

The published fire ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd. does not accept responsibility for the consequences of using Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advice should be sought where such applications are contemplated. The information contained in this drawing is believed to be correct at the date of publication, and is based upon tested and certified solutions. The policy of Rockwool Ltd. is one of constant improvement. Installers should therefore ensure that theis trabilished drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this drawing may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of Rockwool products.

#### **ROCKWOOL Standard Detail:**

Supporting Test Data : WF 411460 (BS EN 1366-3:2009)

The supporting construction must be capable of achieving the required fire rating of the proposed firestop.

Flexible wall constructions must be installed in accordance with the manufacturer's guidelines. The wall construction should be a minimum thickness of 75mm.

All service items should be adequately supported both sides of the firestop to ensure that no load is transferred onto the firestop seal.

Point any gaps between copper sleeve and flexible wall with a bead of ROCKWOOL Acoustic Intumescent Sealant.

Applications in flexible wall constructions can be used in masonry wall constructions.

Refer to relevant product datasheet for further installation guidelines.

These products should only be utilised for applications as outlined in the relevant ROCKWOOL product data sheet and in accordance with the relevant ROCKWOOL Fire Resistance Testing. Additionally the product must be installed in accordance with the current ROCKWOOL guidelines.

For further information please visit <u>www.rockwool.co.uk</u> or contact our Technical Solutions Team on 01656 868490.

ntegrity I	Performance:	Insulation Perfe	ormance:
	60 minutes	up to 60	minutes
	Penco South W t: 014 technical.solut	ed, Bridgend, /ales CF35 6N` 656 868490 ions@rockwoo	Y bl.co.uk
Drawing <sup>-</sup>	Title:		
ROC 75mr	KWOOL FIREPRO n Flexible Wall - 1	)® Acoustic Intun no. Board - Cu. S	nescent Sealant leeved Cables
Scale:	NTS	Date: NOV 20	
Sheet Siz	ze: A3	Drawn By: S. HIRONS	Checked By: L.HAM

Revision:

Drawing Number:

RWSD-AIS-0101

# Appendix UL-EU CERTIFICATE

Certificate No. Page Date of Issue UL-EU-01203-CPR 31/45 2021-09-28

### **Penetration Seals**

Flexible or Rigid Walls Minimum Thickness 75mm

Metallic pipes

Flexible or Rigid Walls ≥75mm Lined/0	Unlined – Insu	lated/Uninsulate	ed	
4.		1.	2.	Key         1.       FirePro Acoustic Intumescent Sealant         2.       Metallic Pipe         3.       Flexible Wall         4.       Backing Material
Penetration Service	Depth (mm)	Annular (mm)	Backing Material	Classification
Copper pipe ≤15mm Ø, 0.7 – 14.2mm wall thickness	ԿՆԿ		<u>u</u>	E 90 C/U, C/C, EI 60 C/U, C/C
Copper/Steel pipe 15 – 54mm Ø, 1.2 – 14.2mm wall thickness	12	5.10	Stone wool or ceramic wool	E 90 C/U, C/C
Steel pipe 15mm Ø, 1 – 14.2mm wall thickness	12	5-10	(≥10mm ≥45kg/m³)	EI 90 C/U, C/C
Steel pipe 15 - 76mm Ø, 2 – 14.2mm wall thickness	i) (i	Nu	n n	E 90 C/U, C/C, EI 20 C/U, C/C
Steel pipe 325mm Ø, 17.5mm wall thickness, insulated with stone wool ≥40mm thick, ≥45kg/m <sup>3</sup> (LI) min. 400mm length to both faces	10	25 (0 distance from aperture edge)	PE backing rod, glass wool, stone wool or ceramic wool	E 60 C/U, C/C, EI 30 C/U, C/C

27-CP-F0855 Issue: 3.1

# **ROCKWOOL** Engineering Judgement

#### **Engineering Judgement request:**

An Engineering Judgement request has been made for justification of the use of ROCKWOOL acoustic intumescent sealant and ROCKWOOL FireStop compound for filling annular gaps around pie penetrations when treated with a Mulcol Multicollar Slim.

#### Justification of proposal:

The Assessment for Multicollar Slim C in walls and floors completed by PEUTZ laboratory for fire safety (Ref: C 1744-1E-RA-010 & C 1744-1E-RA-011) refers to annular gaps around penetrations being filled with Mulcol Multimortar or equal (Mortar EN 13501-1: class1).

ROCKWOOL high strength compound has been classified in accordance with EN 13501-1 (Ref: WF 401213) which deemed the compound has a reaction to fire of class A1 making it suitable for use according to the PEUTZ assessment. ROCKWOOL FireStop compound (normal) has been tested to BE EN 1366-3 which formed the basis of a classification report provided by EXOVA Warrington Fire in accordance with EN 13501- 2 (Ref: WF 389239). It is our opinion that ROCKWOOL standard compound would achieve a reaction to fire class A1 if this product was classified in accordance with EN 13501-1.

ROCKWOOL Acoustic Intumescent Sealant (AIS) is an acrylic based fire stopping sealant which has been extensively tested to BS EN 1366-3 and 4 as well as having a European Technical Assessment (ETA 15/0326 & 15-0327). In our view these supporting documents provide evidence that AIS is an equivalent to the Mulcol Multisealant A referenced in the PEUTZ assessment.

The above specifically relates to ROCKWOOL products being used in conjunction with the Mulcol Multicollar Slim collar as equivalent products to those referenced in the assessments. We are given further confidence in the use of ROCKWOOL products in these applications when referring to IFC PAR 12482\_01 (B). Which gives details on sealing annular gaps around ROCKWOOL Pipe Collars using FireStop Compound & AIS in a similar way to those referenced in the Mulcol assessments.

In terms of providing a smoke seal, gypsum based mortar seals are deemed to be similar to concrete in terms or air tightness. Within the AIS European Technical Assessment the sealant was tested in accordance with BS EN 1314-1. The sealant was found to provide zero air leakage under negative and positive pressure at 100 Pa.

The published fire ratings have been achieved by following the instructions set out above. Use of alternative components or deviations from the instructions in any way is likely to mean that the installation will not comply with the assessed rating. Rockwool Ltd. does not accept responsibility for the consequences of using Rockwool products in applications or for purposes not authorised by Rockwool Ltd. Expert advice should be sought where such applications are contemplated.

The information contained in this drawing is believed to be correct at the date of publication, and is based upon tested and certified solutions. The policy of Rockwool Ltd. is one of constant improvement. Installers should therefore ensure that they are working from the latest published drawings and instructions. Whilst Rockwool will endeavour to keep its publications up to date the accuracy of the information contained within this detail may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of Rockwool products.

ROCKWOOL LIMITED Pencoed, Bridgend, South Wales CF35 6NY T: 01656 862 261

#### **Engineering Judgement**

Rockwool Reference No:

RWEJ-20180927-02-A-RW

**Client: Galaxy** 

Project: Mulcol Multicollar Slim

#### **Fire Resistance Requirements**

Integrity: n/a

Insulation: n/a

#### **Supporting Data:**

WF 401213 / WF 389239 ETA 15/0326 & 15/0327 IFC PAR 12482 01 (B)

#### **Prepared by:**

Lewis Ham

Fire Design Engineer

This detail has been prepared for where an application sits outside of Rockwool test data and has been assessed as the most likely solution to achieve the detailed fire rating. If however a formal Fire Rating is required then this must be obtained via a formal test/assessment from a suitably accredited UKAS Fire Laboratory.

The judgement relates to the expected Fire Resistance performance, should the detail be subjected to a test in accordance with BS 476: Part 20 (unless specified otherwise) against which this judgement has been made.

This Judgement is only suitable for the above referenced project and shall be submitted to the site design team for their approval of the details acceptability.

### **CREATE AND PROTECT®**

# FIRAS Contract in hand form submitted - TX1830

URN	TX1830
Client Name	BAM Construction
Installation Address	Pathology Building LTHT Gledhow Road Harehills
Installation Town	Leeds
Installation County	West Yorkshire
Installation Postcode	LS8 5ER
Contractor Ref	206
Onsite Contact	Simon Jones
Onsite Phone	07738320885
Start Date	05/12/2022
Completion Date	16/04/2023
Other Information	We are also installing the SFS, Partitions and Ceilings on this project but only the Fire Penetration Seals fall within the Scope of our Accreditation

Value of Fire Protection Works	50000
Scope of Job	New Build
Phase	

Product Type	Manufacturer	Product	Fire Protection
Penetration Sealing	Rockwool	Acoustic Intumescent Sealant	60 minutes
Penetration Sealing	Rockwool	50mm Ablative Batt	60 minutes
Penetration Sealing	Rockwool	Firepro Collar	60 minutes
Penetration Sealing	Rockwool	HE Mastic	60 minutes
Penetration Sealing	Rockwool	Firepro Compound	60 minutes
Penetration Sealing	Mulcol	Multicollar Slim	60 minutes
Penetration Sealing	Ultra	Pipe Wrap Ultra	60 minutes
Penetration Sealing	Rockwool	H&V Pipe Insulation	60 minutes
Penetration Sealing	Rockwool	Pipe Wrap Roll	60 minutes
Penetration Sealing	Rockwool	Acoustic Intumescent Sealant	120 minutes
Penetration Sealing	Rockwool	50mm Ablative Batt	120 minutes

Submitted By	Mathew Bates
Items outside scope of work of Installation Company and exceptions	All other Sparta works are outside the scope of this Firas Accreditation, the only items within the scope are the Penetration Sealing works through Fire Rated Partitions.
Created Date	10/10/2022

![](_page_64_Picture_0.jpeg)

## Certificate No. EZ8113

This is to certify that:

# **SPARTA SYSTEMS**

At the following address:

Unit 2, West Chevin Business Centre, West Chevin Road, West Yorkshire, LS21 3HA

complies with the requirements of:

# FIRAS CERTIFICATION SCHEME

## Application of passive fire resisting products using

## **Penetration Sealing Systems**

To check the current validity of this certificate please contact FIRAS direct or visit our website www.firas-database.co.uk

This certification is provided to the client for its own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose

Issue No : 2 Issue Date: 29<sup>th</sup> August 2019 Original Issue Date: 31<sup>st</sup> March 2017 Valid to : 31<sup>st</sup> March 2024

![](_page_64_Picture_13.jpeg)

Paul Duggan EWC Certification Manager

#### **Contact Details**

Employee Name		Firas ID			Photo		
Graham Jennings		T45386					
Position / Job Title		Email					
Technician		mbates@spartasystems.co.uk					
Status		Level of Assessment			1987		
Approved	~	Technician		~		ash	
Give any other details relevant to your application (eg. national vocational qualifications)					-	E.	
Moved To 'Sparta Systems' from 'GWN Contr	racts Limited' on 04/02/2019,						
Product Groups Assessed as Competent							
					Level	Date Awarded	Reassess Due
Penetration Sealing					Technician	08/07/2014	08/07/2023
FIRAS Assessment History							
Date	Module		Level				
08/07/2014	Penetration Sealing		Technician				

#### **Contact Details**

![](_page_66_Picture_1.jpeg)

Supervisor

Penetration Sealing

22.	10 E	In n-	
11/	6151	201	11
1.17	0.01	20	